

GRID CONTROLLER OF INDIA LIMITED
National Load Despatch Centre



From: The Shift Charge Manager, NLDC

To: The Shift Charge Manager, NRLDC/WRLDC/ERLDC/SRLDC

Date: 7/26/2023
Time: 12:23:12 AM

Sl.No	Corridor	Current TTC(MW)	Current ATC(MW)	Revised TTC(MW)	Revised ATC(MW)	Change in ATC (MW)	Date for which Revision is done(dd-mm-yyyy)	Time Block for Revision(From TB)	Time Block for Revision(To TB)	Reason for Revision/Event for which TTC/ATC Revision is being done
1	ER-SR	5700	5350	5550	5200	-150	2023-07-26	3	48	tripped at Bhadrawati end on Yph to earth fault
2	WR-SR	11600	10950	10700	10050	-900	2023-07-26	3	48	tripped at Bhadrawati end on Yph to earth fault
3	SR_IMPORT	17300	16300	16250	15250	-1050	2023-07-26	3	48	tripped at Bhadrawati end on Yph to earth fault
4	SR-WR	6000	5350	5750	5100	-250	2023-07-26	3	24	tripped at Bhadrawati end on Yph to earth fault
5	SR_EXPORT	5000	4350	4750	4100	-250	2023-07-26	3	24	tripped at Bhadrawati end on Yph to earth fault
6	SR-WR	6500	5850	6250	5600	-250	2023-07-26	25	48	tripped at Bhadrawati end on Yph to earth fault
7	SR_EXPORT	5200	4550	4950	4300	-250	2023-07-26	25	48	tripped at Bhadrawati end on Yph to earth fault

SCE-NLDC