

**National Load Despatch Centre  
Total Transfer Capability for April 2021**

Issue Date: 14th April, 2021

Issue Time: 1730 hrs

Revision No. 20

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR*	1st April 2021 to 30th April 2021	00-06	2500	500	2000	253	1747		
		06-18				1339	661		
		18-24				253	1747		
WR-NR*	1st April 2021	00-06	17850 16900**	500	17350 16400**	10993 9983**	6417		
		06-08	17850 16900**			11322 10372**			
		08-18	15800 14850**	500	15300 14350**	11322 10372**	3978		
		18-24	15800 14850**			10993 9983**		4367	
WR-NR*	2nd April 2021 to 12th April 2021	00-06	17850 16900**	500	17350 16400**	10993 9983**	6417		
		06-18	17850 16900**			11322 10372**		6028	
		18-24	17850 16900**	10993 9983**	6417				
WR-NR*	13th April 2021	00-06	17850 16900**	500		17350 16400**	10993 9983**	6417	
		06-08	17850 16900**		11322 10372**		6028		
		08-18	15950 15000**	500	15450 14500**	11322 10372**		4128	
		18-24	15950 15000**			10993 9983**	4517		
WR-NR*	14th April 2021 to 30th April 2021	00-06	17850 16900**	500	17350 16400**	10993 9983**		6417	
		06-18	17850 16900**			11322 10372**	6028		
		18-24	17850 16900**	10993 9983**	6417				

**National Load Despatch Centre  
Total Transfer Capability for April 2021**

Issue Date: 14th April, 2021

Issue Time: 1730 hrs

Revision No. 20

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
NR-ER*	1st April 2021 to 30th April 2021	00-06	2000	200	1800	193	1607			
		06-18	2000		1800	603	1197			
		18-24	2000		1800	193	1607			
ER-NR*	1st April 2021	00-08	5500	300	5200	4280	920			
		08-24	4700	300	4400	4280	120			
ER-NR*	2nd April 2021 to 12th April 2021	00-24	5500	300	5200	4280	920			
ER-NR*	13th April 2021	00-08	5500	300	5200	4280	920			
		08-24	4800	300	4500	4280	220			
ER-NR*	14th April 2021 to 30th April 2021	00-24	5500	300	5200	4280	920			
W3-ER	1st April 2021 to 30th April 2021	00-24	No limit is being specified.							
ER-W3	1st April 2021 to 30th April 2021	00-24	No limit is being specified.							
WR-SR <sup>^</sup>	1st April 2021 to 14th April 2021	00-05	9300	650	8650	3873	4777			
		05-22	9300		8650		4777			
		22-24	9300		8650		4777			
WR-SR <sup>^</sup>	15th April 2021	00-05	9300	650	8650	3873	4777			
		05-22	9300		8650		4777			
		22-24	9300		8650		4777			
WR-SR <sup>^</sup>	16th April 2021	00-05	9300	650	8650	3873	4777	-50	TTC/ATC revised due to continuous s/d of 400KV/220KV 315 MVA ICT 1 AT JEYPORE	
		05-22	9300		8650		4777	-50		
		22-24	9300		8650		4777	-50		
WR-SR <sup>^</sup>	17th April 2021 to 30th April 2021	00-05	9350	650	8700	3873	4827			
		05-22	9350		8700		4827			
		22-24	9350		8700		4827			
SR-WR*	1st April 2021 to 30th April 2021	00-24	4600	400	4200	550	3650			
ER-SR <sup>^</sup>	1st April 2021	00-06	5450	350	5100		2672	2428		
		06-18					2757	2343		
		18-24					2672	2428		
ER-SR <sup>^</sup>	2nd April 2021	00-06	5450	350	5100		2672	2428		
		06-10					5100	2757		2343
		10-18					3250	2757		493
		18-24					3250	2672		578
ER-SR <sup>^</sup>	3rd April 2021 to 14th April 2021	00-06	5450	350	5100		2672	2428		
		06-18					2757	2343		
		18-24					2672	2428		
ER-SR <sup>^</sup>	15th April 2021	00-06	5450	350	5100		2672	2428		
		06-18					2757	2343		
		18-24					2672	2428		
ER-SR <sup>^</sup>	16th April 2021	00-06	5450	350	5100		2672	2428	-300	
		06-18					2757	2343		-300
		18-24					2672	2428		-300

**National Load Despatch Centre  
Total Transfer Capability for April 2021**

Issue Date: 14th April, 2021

Issue Time: 1730 hrs

Revision No. 20

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
ER-SR <sup>^</sup>	17th April 2021 to 30th April 2021	00-06	5750	350	5400	2672	2728			
		06-18				2757	2643			
		18-24				2672	2728			
SR-ER *	1st April 2021 to 30th April 2021	00-24	No limit is being Specified.							
ER-NER*	1st April 2021 to 7th April 2021	00-02	1430	45	1385	474	911			
		02-07	1430			1385	474	911		
		07-12	1430			1385	474	911		
		12-18	1430			1385	474	911		
		18-22	1250			1205	474	731		
		22-24	1430			1385	474	911		
ER-NER*	8th April 2021 to 15th April 2021	00-02	1530	45	1485	474	1011			
		02-07	1530			1485	474	1011		
		07-12	1530			1485	474	1011		
		12-18	1530			1485	474	1011		
		18-22	1380			1335	474	861		
		22-24	1530			1485	474	1011		
ER-NER*	16th April 2021	00-02	1530	45	1485	474	1011	230	Revised TTC/ATC due to shutdown of 400kV Byrnihat - Bongaigoan line and extension of shutdown of Palatana Module 1 & 2	
		02-07	1530			1485	474	1011		230
		07-09	1530			1485	474	1011		230
		09-12	1150			1105	474	631		-150
		12-18	1150			1105	474	631		-150
		18-22	1000			955	474	481		-50
ER-NER*	17th April 2021 to 19th April 2021	00-02	1530	45	1485	474	1011	230	Revised TTC/ATC due to extension of shutdown of Palatana Module 1 & 2	
		02-07	1530			1485	474	1011		230
		07-12	1530			1485	474	1011		230
		12-18	1530			1485	474	1011		230
		18-22	1380			1335	474	861		330
		22-24	1530			1485	474	1011		230
ER-NER*	20th April 2021 to 30th April 2021	00-02	1300	45	1255	474	781			
		02-07	1300			1255	474	781		
		07-12	1300			1255	474	781		
		12-18	1300			1255	474	781		
		18-22	1050			1005	474	531		
		22-24	1300			1255	474	781		
NER-ER*	1st April 2021 to 7th April 2021	00-02	3000	45	2955	83	2872			
		02-07	3000			2955	83	2872		
		07-12	3000			2955	83	2872		
		12-18	3000			2955	83	2872		
		18-22	2930			2885	83	2802		
		22-24	3000			2955	83	2872		
NER-ER*	8th April 2021 to 15th April 2021	00-02	2730	45	2685	83	2602			
		02-07	2730			2685	83	2602		
		07-12	2730			2685	83	2602		
		12-18	2730			2685	83	2602		
		18-22	2650			2605	83	2522		
		22-24	2730			2685	83	2602		
NER-ER*	16th April 2021 to 19th April 2021	00-02	2730	45	2685	83	2602	-560	Revised TTC/ATC due to extension of shutdown of Palatana Module 1 & 2	
		02-07	2730			2685	83	2602		-560
		07-12	2730			2685	83	2602		-560
		12-18	2730			2685	83	2602		-560
		18-22	2650			2605	83	2522		-560
		22-24	2730			2685	83	2602		-560
NER-ER*	20th April 2021 to 30th April 2021	00-02	3290	45	3245	83	3162			
		02-07	3290			3245	83	3162		
		07-12	3290			3245	83	3162		
		12-18	3290			3245	83	3162		
		18-22	3210			3165	83	3082		
		22-24	3290			3245	83	3162		

**W3 zone Injection** 1st April 2021 to 30th April 2021 00-24 No limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly)

**Note:** TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.

**National Load Despatch Centre  
Total Transfer Capability for April 2021**

Issue Date: 14th April, 2021

Issue Time: 1730 hrs

Revision No. 20

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
<p>* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral &amp; First Come First Serve).</p>									
<p>**Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.</p>									
<p>1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala                  2) W3 comprises of the following regional entities :                  a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I &amp; Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak                  f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCCL, n)Vandana Vidyt o)RKM, p)GMR Raikheda, q)Ind Barath                  and any other regional entity generator in Chhattisgarh</p> <p># The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissioned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.</p> <p>In case of TTC Revision due to any shutdown :</p> <p>1) The TTC value will be revised to normal values after restoration of shutdown.                  2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.</p> <p>Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section</p> <p>^Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of WR-SR and ER-SR corridor has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implemetation.</p> <p>^In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka SLDC by taking appropriate measures.</p> <p>SR-WR TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.</p> <p>WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.</p>									

Simultaneous Import Capability									
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st April 2021	00-06	23350	800	22550	15213	7337		
			22400**		21600**	14263**			
		06-08	23350		22550	15602	6948		
			22400**		21600**	14652**			
		08-17	20500		19700	15602	4098		
			19550**		18750**	14652**			
17-18	20500	19700	15602	4098					
	19550**	18750**	14652**						
18-24	20500	19700	15213	4487					
	19550**	18750**	14263**						
NR*	2nd April 2021 to 12th April 2021	00-06	23350	800	22550	15213	7337		
			22400**		21600**	14263**			
		06-09	23350		22550	15602	6948		
			22400**		21600**	14652**			
		09-17	23350		22550	15602	6948		
			22400**		21600**	14652**			
17-18	23350	22550	15602	6948					
	22400**	21600**	14652**						
18-24	23350	22550	15213	7337					
	22400**	21600**	14263**						
NR*	13th April 2021	00-06	23350	800	22550	15213	7337		
			22400**		21600**	14263**			
		06-08	23350		22550	15602	6948		
			22400**		21600**	14652**			
		08-17	20750		19950	15602	4348		
			19800**		19000**	14652**			
17-18	20750	19950	15602	4348					
	19800**	19000**	14652**						
18-24	20750	19950	15213	4737					
	19800**	19000**	14263**						

<b>NR*</b>	14th April 2021 to 30th April 2021	00-06	23350 22400**	800	22550 21600**	15213 14263**	7337		
		06-09	23350 22400**		22550 21600**	15602 14652**	6948		
		09-17	23350 22400**		22550 21600**	15602 14652**	6948		
		17-18	23350 22400**		22550 21600**	15602 14652**	6948		
		18-24	23350 22400**		22550 21600**	15213 14263**	7337		
<b>NER*</b>	1st April 2021 to 7th April 2021	00-02	1430	45	1385	474	911		
		02-07	1430		1385	474	911		
		07-12	1430		1385	474	911		
		12-18	1430		1385	474	911		
		18-22	1250		1205	474	731		
		22-24	1430		1385	474	911		
<b>NER*</b>	8th April 2021 to 15th April 2021	00-02	1530	45	1485	474	1011		
		02-07	1530		1485	474	1011		
		07-12	1530		1485	474	1011		
		12-18	1530		1485	474	1011		
		18-22	1380		1335	474	861		
		22-24	1530		1485	474	1011		
<b>NER*</b>	16th April 2021	00-02	1530	45	1485	474	1011	230	Revised TTC/ATC due to shutdown of 400kV Byrnihat - Bongaigoan line and extension of shutdown of Palatana Module 1 & 2
		02-07	1530		1485	474	1011	230	
		07-09	1530		1485	474	1011	230	
		09-12	1150		1105	474	631	-150	
		12-18	1150		1105	474	631	-150	
		18-22	1000		955	474	481	-50	
<b>NER*</b>	17th April 2021 to 19th April 2021	00-02	1530	45	1485	474	1011	230	Revised TTC/ATC due to extension of shutdown of Palatana Module 1 & 2
		02-07	1530		1485	474	1011	230	
		07-12	1530		1485	474	1011	230	
		12-18	1530		1485	474	1011	230	
		18-22	1380		1335	474	861	330	
		22-24	1530		1485	474	1011	230	
<b>NER*</b>	20th April 2021 to 30th April 2021	00-02	1300	45	1255	474	781		
		02-07	1300		1255	474	781		
		07-12	1300		1255	474	781		
		12-18	1300		1255	474	781		
		18-22	1050		1005	474	531		
		22-24	1300		1255	474	781		
<b>WR*</b>									
<b>SR**</b>	1st April 2021	00-06	14750	1000	13750	6545	7205		
		06-18	14750		13750	6630	7120		
		18-24	14750		13750	6545	7205		
<b>SR**</b>	2nd April 2021	00-06	14750	1000	13750	6545	7205		
		06-10	14750		14750	6630	8120		
		10-18	12900		11900	6630	5270		
		18-24	12900		11900	6545	5355		
<b>SR**</b>	3rd April 2021 to 14th April 2021	00-06	14750	1000	13750	6545	7205		
		06-18	14750		13750	6630	7120		
		18-24	14750		13750	6545	7205		
<b>SR**</b>	15th April 2021	00-06	14750	1000	13750	6545	7205		
		06-18	14750		13750	6630	7120		
		18-24	14750		13750	6545	7205		

<b>SR**</b>	16th April 2021	00-06	14750	1000	13750	6545	7205	-350	TTC/ATC revised due to continuous s/d of 400KV/220KV 315 MVA ICT 1 AT JEYPORE
		06-18	14750		13750	6630	7120	-350	
		18-24	14750		13750	6545	7205	-350	
<b>SR**</b>	17th April 2021 to 30th April 2021	00-06	15100	1000	14100	6545	7555		
		06-18	15100		14100	6630	7470		
		18-24	15100		14100	6545	7555		

\* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

\*\*Considering 400 kV Rihand stage-III - Vindhyaachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

\* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Margin in Simultaneous import of NR = A

WR-NR ATC = B

ER-NR ATC = C

Margin for WR-NR applicants =  $A * B / (B+C)$

Margin for ER-NR Applicants =  $A * C / (B+C)$

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

#Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of SR Import has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.

In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka by taking appropriate measures.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

Simultaneous Export Capability									
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st April 2021 to 30th April 2021	00-06	4500	700	3800	446	3354		
		06-18			3800	1942	1858		
		18-24	4500		3800	446	3354		
NER*	1st April 2021 to 7th April 2021	00-02	3000	45	2955	83	2872		
		02-07	3000		2955	83	2872		
		07-12	3000		2955	83	2872		
		12-18	3000		2955	83	2872		
		18-22	2930		2885	83	2802		
		22-24	3000		2955	83	2872		
NER*	8th April 2021 to 15th April 2021	00-02	2730	45	2685	83	2602		
		02-07	2730		2685	83	2602		
		07-12	2730		2685	83	2602		
		12-18	2730		2685	83	2602		
		18-22	2650		2605	83	2522		
		22-24	2730		2685	83	2602		
NER*	16th April 2021 to 19th April 2021	00-02	2730	45	2685	83	2602	-560	Revised TTC/ATC due to extension of shutdown of Palatana Module 1 & 2
		02-07	2730		2685	83	2602	-560	
		07-12	2730		2685	83	2602	-560	
		12-18	2730		2685	83	2602	-560	
		18-22	2650		2605	83	2522	-560	
		22-24	2730		2685	83	2602	-560	
NER*	20th April 2021 to 30th April 2021	00-02	3290	45	3245	83	3162		
		02-07	3290		3245	83	3162		
		07-12	3290		3245	83	3162		
		12-18	3290		3245	83	3162		
		18-22	3210		3165	83	3082		
		22-24	3290		3245	83	3162		
WR*									
SR*^	1st April 2021 to 30th April 2021	00-24	3700	400	3300	1150	2150		
* Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).									
Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section									
^SR Export TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.									



<b>Limiting Constraints (Corridor wise)</b>			<b>Applicable Revisions</b>
<b>Corridor</b>	<b>Constraint</b>		
<b>WR-NR</b>	N-1 contingency of 1500 MVA, 765/400 kV ICT at Agra will overload the other ICT		Rev- 0 to 20
<b>NR-ER</b>	(n-1) contingency of 400 kV Saranath-Pusauli		Rev- 0 to 20
<b>ER-NR</b>	1. N-1 contingency of 400 kV Mejia-Maithon A line will overload the other ckt. 2. Inter-regional flow pattern towards NR		Rev- 0 to 20
<b>WR-SR and ER-SR</b>	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT		Rev- 0 to 20
	Low Voltage at Gazuwaka (East) Bus.		
<b>SR-WR</b>	a) N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt b) N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs		Rev- 0 to 20
<b>ER-NER</b>	a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Salakati - BTPS D/C		Rev- 0 to 20
<b>NER-ER</b>	a) N-1 contingency of 400 kV Silchar- Azara line b) High Loading of 220/132 kV,100 MVA Dimapur ICT-2		Rev- 0 to 20
<b>W3 zone Injection</b>	---		Rev- 0 to 20
<b>Limiting Constraints (Simultaneous)</b>			<b>Applicable Revisions</b>
<b>NR</b>	<b>Import</b>	1. N-1 contingency of 400 kV Mejia-Maithon A line will overload the other ckt. 2. Inter-regional flow pattern towards NR	Rev- 0 to 20
		N-1 contingency of 1500 MVA, 765/400 kV ICT at Agra will overload the other ICT	
	<b>Export</b>	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli	Rev- 0 to 20
<b>NER</b>	<b>Import</b>	a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Salakati - BTPS D/C	Rev- 0 to 20
	<b>Export</b>	a) N-1 contingency of 400 kV Silchar- Azara line b) High Loading of 220/132 kV,100 MVA Dimapur ICT-2	Rev- 0 to 20
<b>SR</b>	<b>Import</b>	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT	Rev- 0 to 20
		Low Voltage at Gazuwaka (East) Bus	
	<b>Export</b>	N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	Rev- 0 to 20

**National Load Despatch Centre  
Total Transfer Capability for April 2021**

Revision No	Date of Revision	Period of Revision	Reason for Revision/Comment	Corridor Affected
1	28th Jan 2021	Apr-21	* LTA figure revised by 41.5 MW after declaration of commercial operation of Kameng HEP (4x150MW) unit-3 w.e.f 00:00Hrs of 22.01.2021	NER-ER/NER Export
2	04th Feb 2021	Whole month	Operationalization of LTA granted to M/s Adani Wind Energy Kutchh Three Limited :-	WR-NR/NR IMPORT
			a) 39.1 MW to UPPCL	
			b) 18.4 MW to Chandigarh	
			c) 34.5 MW to KSEB	WR-SR/SR IMPORT
3	09th Feb 2021	Whole Month	Operationalization of LTA granted to M/s Alfanar Energy Private Limited on available margins at Bhuj PS :- a) 14.4 to BSES Rajdhani Power Limited , Delhi b) 4.7 to BSES Yamuna Power Limited , Delhi c) 4.7 to TATA Power Delhi Distribuion Limited	WR-NR/NR IMPORT
4	12th Feb 2021	Whole Month	Revised due to operationalisation of 300MW MTOA granted form Azure Solar Power ,Rajasthan to Odisha	NR-ER/ NR Export
			Revised due to revised LTA granted for transfer of power from Nabinagar-1	ER-NR/ NR Import
5	27th Feb 2021	Whole Month	Revised STOA margin due to operationalisation of 99 MW LTA from Chuzachen HEP to Haryana	ER-NR
			Revised STOA margin due to change in LTA allocation of RPL-SECI-II-RE, ALFANAR_SECI-III and RWE_APL2_SECI-III(Ghadsisa)	WR-NR
			Revised STOA margin due to change in LTA allocations.	WR-SR, ER-SR/ SR Import
			Revised TTC/ATC due to -	
			1) Change in Load-Generation of NER	
			2) Addition of 4th unit (1x150 MW) of 4 x 150 MW Kameng Generation	
			3) Commissioning of 400 kV SM Nagar (ISTS) - PK Bari (ISTS) D/C	NER Import /NER Export
			4) Commissioning of 400 kV Silchar - Misa D/C	
6	11th Mar 2021	Whole Month	TTC/ATC revised due to commissioning of HVDC Raigarh-Pugalur Pole 2	WR-SR, ER-SR/ SR Import
7	16th Mar 2021	Whole month	Revision in STOA due to operationalization of LTA 12.3 MW from AWEK3L to UPPCL/NR	WR-NR/NR Import
			Revision in STOA due to operationalization of LTA 10.9 MW from AWEK3L to KSEB/SR	WR-SR/SR Import
8	17th Mar 2021	Whole Month	Revised ATC due to increase in Reliability Margin from 750 MW to 1000 MW due to high SR demand	WR-SR, ER-SR/ SR Import
9	28th March 2021	Whole Month	Revised STOA margin due to change in LTA allocation by 58MW from NR ISGS to Gujrat	NR-WR/NR Export
			Revised STOA margin due to change in LTA allocations	WR-NR/NR IMPORT
			Revised TTC/ATC due to -	
			1) Change in Load-Generation of NER	
			2) Addition of 4th unit (1x150 MW) of 4 x 150 MW Kameng Generation	
			3) Commissioning of 400 kV SM Nagar (ISTS) - PK Bari (ISTS) D/C	NER Import /NER Export
			4) Commissioning of 400 kV Silchar - Misa D/C	
			5) Commissioning of 400 kV Silchar - PK Bari D/C	
10	30th March 2021	01st April 2021	TTC/ATC revised due to s/d of 765 KV AGRA-JHATIKARA (PG) CKT-1	WR-NR,ER-NR/NR IMPORT
		01st April 2021 to 3rd April 2021	TTC/ATC revised due to continuous s/d of 400KV/220KV 315 MVA ICT 1 AT JEYPORE	WR-SR, ER-SR/ SR Import
		01st April 2021 to 10th April 2021	TTC/ATC revised due to Shutdown of 4x150 MW Kameng HEP	NER Import /NER Export
11	30th March 2021	02nd April 2021	TTC/ATC revised due to s/d of HVDC Talcher-Kolar Pole-1 & 2	ER-SR/ SR Import
12	02nd April 2021	04th April 2021	TTC/ATC revised due to continuous s/d of 400KV/220KV 315 MVA ICT 1 AT JEYPORE	WR-SR, ER-SR/ SR Import
13	3rd April 2021	5th April 2021	TTC/ATC revised due to continuous s/d of 400KV/220KV 315 MVA ICT 1 AT JEYPORE	WR-SR, ER-SR/ SR Import
14	4th April 2021	6th April 2021	TTC/ATC revised due to continuous s/d of 400KV/220KV 315 MVA ICT 1 AT JEYPORE	WR-SR, ER-SR/ SR Import
15	5th April 2021	7th April 2021 to 12th April 2021	TTC/ATC revised due to continuous s/d of 400KV/220KV 315 MVA ICT 1 AT JEYPORE	WR-SR, ER-SR/ SR Import
16	6th April 2021	8th April 2021 to 14th April 2021	Revised TTC/ATC due to Shutdown of Palatana Module 1&2	NER Import /NER Export
17	11th April 2021	13th April 2021	TTC/ATC revised due to s/d of 765 KV GR.NOIDA (UPC)-ALIGARH(PG) S/C	WR-NR,ER-NR/NR IMPORT
			TTC/ATC revised due to continuous s/d of 400KV/220KV 315 MVA ICT 1 AT JEYPORE	WR-SR, ER-SR/ SR Import
18	12th April 2021	14th April 2021	TTC/ATC revised due to continuous s/d of 400KV/220KV 315 MVA ICT 1 AT JEYPORE	WR-SR, ER-SR/ SR Import

19	13th April 2021	15th April 2021	TTC/ATC revised due to continuous s/d of 400KV/220KV 315 MVA ICT 1 AT JEYPORE	WR-SR, ER-SR/ SR Import
20	14th April 2021	16th April 2021	TTC/ATC revised due to continuous s/d of 400KV/220KV 315 MVA ICT 1 AT JEYPORE	WR-SR, ER-SR/ SR Import
		16th April 2021	Revised TTC/ATC due to shutdown of 400kV Byrnihat - Bongaigoan line and extension of shutdown of Palatana Module 1 & 2	NER Import
		17th April 2021 to 19th April 2021	Revised TTC/ATC due to extension of shutdown of Palatana Module 1 & 2	NER Import
		16th April 2021 to 19th April 2021	Revised TTC/ATC due to extension of shutdown of Palatana Module 1 & 2	NER Export

ASSUMPTIONS IN BASECASE					
				Month : April 2021	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)		Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	6227	4997	3097	2902
2	Haryana	7801	6031	2202	2202
3	Rajasthan	10163	12851	7039	7011
4	Delhi	5647	5052	678	678
5	Uttar Pradesh	17979	14878	8867	8792
6	Uttarakhand	1969	1574	930	790
7	Himachal Pradesh	1555	1274	444	392
8	Jammu & Kashmir	2495	2176	433	436
9	Chandigarh	239	153	0	0
10	ISGS/PPs	18	18	18785	13577
	Total NR	54093	49005	42475	36780
II	EASTERN REGION				
1	Bihar	4820	3188	352	344
2	Jharkhand	1522	1046	378	353
3	Damodar Valley Corporation	2784	2584	4559	3683
4	Orissa	3806	3184	3165	2611
5	West Bengal	7328	5393	5270	4142
6	Sikkim	110	44	0	0
7	Bhutan	160	165	440	554
8	ISGS/PPs	-160	-165	12395	8633
	Total ER	20369	15439	26559	20318
III	WESTERN REGION				
1	Maharashtra	19941	15342	14113	11160
2	1st April 2021 to 5th April 2021	17919	12325	13029	8865
3	Madhya Pradesh	11036	6707	5302	3136
4	Chattisgarh	4288	2679	2873	2590
5	6th April 2021 to 30th April 2021	337	272	0	0
6	Dadra and Nagar Haveli	873	771	0	0
7	Goa-WR	584	428	0	0
8	ISGS/PPs	5609	4727	39129	29849
	Total WR	60586	43252	74445	55600

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)		Peak (MW)	Off Peak (MW)
IV	SOUTHERN REGION				
1	Andhra Pradesh	8713	8774	6825	6825
2	Telangana	9357	8553	5042	4642
3	Karnataka	9140	9202	8283	8283
4	Tamil Nadu	16143	13975	6532	5690
5	Kerala	4156	2952	1658	581
6	3rd April 2021 to 5th April 2021	264	265	0	0
7	Goa-SR	41	41	0	0
8	ISGS/IPPs	9	9	13941	13941
	6th April 2021 to 30th April 2021	47822	43773	42281	39963
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	105	103	0	0
2	Assam	1433	1150	255	195
3	Manipur	203	100	0	0
4	Meghalaya	313	273	231	167
5	Mizoram	132	47	53	35
6	Nagaland	160	144	12	12
7	Tripura	384	235	154	156
8	ISGS/IPPs	0	0	0	0
	Total NER	2731	2052	705	565
	Total All India	185602	153519	186465	153226