National Load Despatch Centre Total Transfer Capability for December 2019

Issue Date: 18th November 2019 Issue Time: 1630 hrs Revision No. 2

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	1st December	00-06				195	1805		
NR-WR*	2019 to 31st	06-18	2500	500	2000	250	1750		
	December 2019	18-24				195	1805		
WR-NR*	1st October 2019 to 31st	00-24	14900 13950**	500	14400	10067	4333		
	October 2019				13450**	9117**	4333**		
NR-ER*	1st December 2019 to 31st	00-06 06-18	2000	200	1800 1800	193 303	1607 1497		
TAK-EK	December 2019	18-24	2000	200	1800	193	1607		
ER-NR*	1st December 2019 to 31st December 2019	00-24	5250	300	4950	4050	900		
W3-ER	1st December 2019 to 31st December 2019	00-24	No limit is being specified.						
ER-W3	1st December 2019 to 31st December 2019	00-24		No limit is being specified.					
WR-SR	1st December 2019 to 31st December 2019	00-05 05-22 22-24	5550 5550 5550	500	5050 5050 5050	3888	1162 1162 1162		
SR-WR*	1st December 2019 to 31st December 2019	00-24				No limit i	is being Specified.		,
		00-06				2748	1952		
ER-SR	1st December 2019 to 31st	06-18	4950	250	4700	2833	1867		
	December 2019	18-24				2748	1952	_	
SR-ER *	1st December 2019 to 31st December 2019	00-24	No limit is being Specified.						
		00-17	1588		1543		1209		
ER-NER	1st December 2019 to 31st	17-23	1244	45	1199	334	865		Revised STOA margin due to 4.2 MW LTA and 19.76 MW
EK-NEK	December 2019	23-24	1588	15	1543	554	1209		MTOA to Assam from GIWEL
	1st December	00-17	2837		2792		2792		
NER-ER	2019 to 31st December 2019	17-23 23-24	2831 2837	45	2786 2792	0	2786 2792		

National Load Despatch Centre Total Transfer Capability for December 2019

Issue Date: 18th November 2019 Issue Time: 1630 hrs Revision No. 2

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
W3 zone Injection	1st December 2019 to 31st December 2019		No limit is be	No limit is being specified (In case of any constraints appearing in the system, W3 zone export would be revised accordingly)					

Note: TTC/ATC of S1-(S2&S3) corridor, Import of S3(Kerala), Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.

- 1) S1 comprises of Telangana, AP and Karnataka; S2 comprises of Tamil Nadu and Puducherry; S3 comprises Kerala
- 2) W3 comprises of the following regional entities:
- a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
- f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n) Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh
- # The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/ Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown:

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

^{**}Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
			20.400		10,000		5.402		
		00.06	20400		19600		5483		
		00-06	19450**		18650**		5483**		
			21900		21100		6983		1
ND	1st December	06-09	20950**	800	20150**	14117 13167**	6983**		
NR	2019 to 31st December 2019	09-17	20400		19600		5483		
			19450**		18650**		5483**		
		17-24	19850		19050		4933		
			18900**		18100**		4933**		
	1st December	00-17	1588		1543		1209		Revised STOA margin due to
NER	2019 to 31st December 2019	17-23	1244	45	1199	334	865		4.2 MW LTA and 19.76 MW MTOA to Assam from GIWEL
	December 2019	23-24	1588		1543		1209		WITOA to Assain Holli OTWEL
WR									
	1.15. 1	00.05	10500		0770		2114		
CD	1st December	00-06	10500	750	9750	6636	3114		
SR	2019 to 31st December 2019	06-18 18-24	10500 10500	750	9750 9750	6721 6636	3029 3114		-
	December 2019	10-24	10300		9730	0030	3114		

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Margin in Simultaneous import of NR = A

WR-NR ATC =B

ER-NRATC = C

Margin for WR-NR applicants = A * B/(B+C)

Margin for ER-NR Applicants = A * C/(B+C)

^{**}Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

^{*} For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	1st December	00-06	4500		3800	388	3412		
NR*	2019 to 31st	06-18	1500	700	3800	553	3247		
	December 2019	18-24	4500		3800	388	3412		
	1st December	00-17	2837	45	2792		2792		
NER	2019 to 31st	17-23	2831		2786	0	2786		
	December 2019	23-24	2837		2792		2792		
WR									
,,,,									
SR *	1st December 2019 to 31st December 2019	00-24		No limit is being Specified.					

^{*} Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Limiting Constraints (Corridor wise)

		Applicable Revisions
Corridor	Constraint	
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Bhanpura-Modak	Rev-0 to 2
WR-NR	n-1 contingency of 765 kV Aligarh - Jhatikara Line will lead to overlaoding of 765 kV Aligarh - Gr. Noida Line	Rev-0 to 2
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	Rev-0 to 2
ER-NR	1. N-1 contingencies of 400 kv Mejia-Maithon A S/C 2. N-1 contingencies of 400 kv Kahalgaon-Banka S/C 3. N-1 contingencies of 400kV MPL- Maithon S/C	Rev-0 to 2
WR-SR	n-1 contingency of 2x315 MVA, 400/220 kV ICTs at Mardam will lead to overloading of the second ICT	Rev-0 to 2
and ER-	n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Vemagiri (PG) will lead to overloading of the second ICT	Rev-0 to 2
SR	Low Voltage at Gazuwaka (East) Bus.	Rev-0 to 2
ER-NER	a. (n-1) contingency of 400/220 kV, 2x500 MVA ICTs at Misa b. High Loading of 220 kV Salakati-BTPS Double circuit (200 MW)	Rev-0 to 2
NER-ER	a. N-I contingency of 400 kV Silchar- Azara Line b. High Loading of 400 kV Bongaigaon-Killing line	Rev-0 to 2
W3 zone Injection		Rev-0 to 2

Limiting Constraints (Simultaneous)

			Applicable Revisions
	Import	 N-1 contingencies of 400 kv Mejia-Maithon A S/C N-1 contingencies of 400 kv Kahalgaon-Banka S/C N-1 contingencies of 400kV MPL- Maithon S/C 	Rev-0 to 2
NR		n-1 contingency of 765 kV Aligarh - Jhatikara Line will lead to overlaoding of 765 kV Aligarh - Gr. Noida Line	Rev-0 to 2
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli	Rev-0 to 2
NER	Import	a. (n-1) contingency of 400/220 kV, 2x500 MVA ICTs at Misab. High Loading of 220 kV Salakati-BTPS Double circuit (200 MW)	Rev-0 to 2
TVEAK	Export	a. N-1 contingency of 400 kV Silchar- Azara Lineb. High Loading of 400 kV Bongaigaon-Killing line	Rev-0 to 2
		n-1 contingency of 2x315 MVA, 400/220 kV ICTs at Mardam will lead to overloading of the second ICT	Rev-0 to 2
SR	Import	n-1 contingency of 2x1500 MVA, 765/400 kV ICTs at Vemagiri (PG) will lead to overloading of the second ICT	Rev-0 to 2
		Low Voltage at Gazuwaka (East) Bus.	Rev-0 to 2

National Load Despatch Centre Total Transfer Capability for December 2019

Revision No	Date of Revision	Period of Revision	Reason for Revision/Comment	Corridor Affected
1	13th September 2019	I Whole Month	Revised considering Load Geneartion balance and HVDC set points as per present system conditions	WR-NR/Import of NR
2	18th November 2019	Whole Month	Revised STOA margin due to 4.2 MW LTA and 19.76 MW MTOA to Assam from GIWEL	ER-NER/Import of NER

ASSUM	IPTIONS IN BASECASE				
				Month : December'19	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
I	NORTHERN REGION				
1	Punjab	7977	6899	4008	3820
2	Haryana	7790	6011	1734	1734
3	Rajasthan	12153	12298	8096	8093
4	Delhi	4983	2942	718	718
5	Uttar Pradesh	14092	13018	6200	6051
6	Uttarakhand	2024	1656	764	398
7	Himachal Pradesh	1531	1094	279	197
8	Jammu & Kashmir	2344	2327	575	542
9	Chandigarh	304	172	0	0
10	ISGS/IPPs	27	27	19267	12445
	Total NR	53225	46445	41640	33997
П	EASTERN REGION				
1	Bihar	4897	3256	168	161
2	Jharkhand	1228	949	369	319
3	Damodar Valley Corporation	2800	2851	4652	3775
4	Orissa	4145	2887	2847	2178
5	West Bengal	7399	5531	5024	3823
6	Sikkim	242	298	0	0
7	Bhutan	183	180	336	281
8	ISGS/IPPs	641	644	12884	9320
	Total ER	21535	16597	26279	19856
Ш	WESTERN REGION				
1	Maharashtra	18000	15576	14005	12734
2	Gujarat	14422	14167	8700	10119
3	Madhya Pradesh	13071	10461	5848	5042
4	Chattisgarh	4019	3534	2670	2520
5	Daman and Diu	325	321	0	0
6	Dadra and Nagar Haveli	807	733	0	0
7	Goa-WR	522	463	0	0
8	ISGS/IPPs	5119	4604	42069	35989
	Total WR	56284	49859	73293	66404

S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
IV	SOUTHERN REGION				
1	Andhra Pradesh	10126	7849	6911	5245
2	Telangana	11656	7173	4899	4314
3	Karnataka	9505	5951	7902	4423
4	Tamil Nadu	14273	11462	6397	5897
5	Kerala	3361	2243	1475	157
6	Pondy	333	309	0	0
7	Goa-SR	65	60	0	0
8	ISGS/IPPs	0	0	18497	12129
	Total SR	49319	35047	46081	32166
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	123	70	0	0
2	Assam	1576	1047	204	176
3	Manipur	223	105	0	0
4	Meghalaya	331	257	144	33
5	Mizoram	99	69	36	28
6	Nagaland	119	79	16	0
7	Tripura	220	139	93	93
8	ISGS/IPPs	138	85	2271	1863
	Total NER	2828	1849	2764	2193
	Total All India	183191	149797	190057	154617