				-	patch Cent ility for Dec	re ember 2021			
Issue Date	: 28th August,	2021	Issu	e Time: 180	0 hrs		R	. 0	
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
		00-06				378	1622		
NR-WR*	1st December 2021 to 31st December 2021	06-18	2500	500	2000	1206	794		
		18-24				378	1622		
		00-06	19500 18550**	1000	18500 17550**	11279 10329**	7221		
WR-NR*	1st December 2021 to 31st	06-18	19500	1000	18500	11668	6832		
	December 2021	18-24	18550** 19500	1000	17550** 18500	10718** 11279	7221		
		10-24	18550**	1000	17550**	10329**	1221		
	1st December	00-06	2000		1800	93	1707		
NR-ER*	2021 to 31st December 2021	06-18 18-24	2000 2000	200	1800 1800	908 93	892 1707	-	
ER-NR*	1st December 2021 to 31st December 2021	00-24	5900	400	5500	4372	1128		
W3-ER	1st December 2021 to 31st December 2021	00-24						No limit is	being specified.
W3-ER ER-W3	2021 to 31st	00-24							being specified.
ER-W3	2021 to 31st December 2021 1st December 2021 to 31st December 2021 1st December	00-24	9350		8700	2504	5104		
	2021 to 31st December 2021 1st December 2021 to 31st December 2021	00-24 00-05 05-22	9350 9350 9350 9350	650	8700 8700 8700 8700	3596	5104 5104 5104 5104		
ER-W3	2021 to 31st December 2021 1st December 2021 to 31st December 2021 1st December 2021 to 31st	00-24 00-05 05-22 22-24 00-24	9350	650	8700	3596	5104		
ER-W3 WR-SR [^]	2021 to 31st December 2021 1st December 2021 to 31st December 2021 1st December 2021 to 31st December 2021 1st December 2021 to 31st December 2021	00-24 00-05 05-22 22-24 00-24	9350 9350		8700 8700	857	5104 5104		
ER-W3 WR-SR [^]	2021 to 31st December 2021 1st December 2021 to 31st December 2021 1st December 2021 to 31st December 2021 1st December 2021 to 31st	00-24 00-05 05-22 22-24 00-24 00-24 00-06 06-18	9350 9350		8700 8700	857 2672 2757	5104 5104 3343 2728 2643		
ER-W3 WR-SR [^] SR-WR *	2021 to 31st December 2021 1st December 2021 to 31st December 2021 1st December 2021 to 31st December 2021 1st December 2021 to 31st December 2021	00-24 00-05 05-22 22-24 00-24 00-24 00-06 06-18 18-24 00-24	9350 9350 4600	400	8700 8700 4200	857	5104 5104 3343 2728	No limit is	
ER-W3 WR-SR^ SR-WR * ER-SR^	2021 to 31st December 2021 1st December 2021 to 31st December 2021	00-24 00-05 05-22 22-24 00-24 00-24 00-06 06-18 18-24 00-24	9350 9350 4600 5750	400	8700 8700 4200 5400	857 2672 2757 2672	5104 5104 3343 2728 2643 2728	No limit is	being specified.
ER-W3 WR-SR^ SR-WR * ER-SR^	2021 to 31st December 2021 1st December 2021 to 31st December 2021	00-24 00-05 05-22 22-24 00-24 00-24 00-06 06-18 18-24 00-24 00-24 00-24	9350 9350 4600	400	8700 8700 4200	857 2672 2757	5104 5104 3343 2728 2643	No limit is	being specified.
ER-W3 WR-SR^ SR-WR * SR-SR^	2021 to 31st December 2021 1st December 2021 to 31st December 2021	00-24 00-05 05-22 22-24 00-24 00-24 00-06 06-18 18-24 00-24 00-24 00-24 00-24 00-24 00-02 02-07 07-12 12-18 18-22 22-24	9350 9350 4600 5750 5750 810 810 810 810 810 810	400	8700 8700 4200 5400 5400 765 765 765 760 775 565 765	857 2672 2757 2672 455 455 455 455 455 455 455	5104 5104 3343 2728 2643 2728 310 310 305 320 110 310	No limit is	being specified.
ER-W3 WR-SR^ SR-WR*	2021 to 31st December 2021 1st December 2021 to 31st December 2021	00-24 00-05 05-22 22-24 00-24 00-24 00-06 06-18 18-24 00-24 00-24 00-24 00-24 00-02 02-07 07-12 12-18 18-22	9350 9350 4600 5750 810 810 810 805 820 610	400	8700 8700 4200 5400 5400 765 765 760 775 565	857 2672 2757 2672 2672 455 455 455 455 455 455	5104 5104 3343 2728 2643 2728 310 310 310 305 320 110	No limit is	being specified.

				Load Desp sfer Capab		tre cember 2021			
Issue Date: 28th August, 2021Issue Time: 1800 hrsRevision No. 0									. 0
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
W3 zone Injection	1st December 2021 to 31st December 2021	00-24	No limit is be	ing specified ()	In case of any o	constraints appeari	ng in the system, W	/3 zone expor	rt would be revised accordingly)
Note: TTC/	ATC of S1-(S2&	&S3) corridor, Impo	ort of S3(Keral	la), Import of	Punjab and I	Import of DD & I	ONH is uploaded	on NLDC we	ebsite under Intra-Regional Section in Monthly ATC.
* Fifty Perce	ent (50 %) Count	ter flow benefit on acc	count of LTA/N	ATOA transact	tions in the rev	erse direction wou	ld be considered for	r advanced tra	ansactions (Bilateral & First Come First Serve).
**Considerin	-	d stage-III - Vindhyac	chal PS D/C lin	e as inter-regio	onal line for the	e purpose of sched	uling, metering and	accounting a	nd 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as
2) W3 compa) Chattisgarf) BALCO, g	rises of the follow h Sell transaction,) Sterlite (#1,3,4)	AP and Karnataka; S2 ving regional entities : , b) Jindal Power Limit , h) NSPCL, i) Korba, enerator in Chhattisgar	ted (JPL) Stage , j) Sipat, k) KS	-I & Stage-II, c	e) Jindal Steel a	nd Power Limited (JSPL), d) ACBL, e)		
Fuel shortag	e/New units bein	/MTOA approved by g commissionned the edules exceed ATC, r	e LTA/MTOA	utilized would	vary. RLDC/N	NLDC would facto	* ·	e	
1) The TTC	value will be rev	to any shutdown : vised to normal values vised to normal values				time.			
Real Time T	TC/ATC revisior	ns are uploaded on PC)SOCO/NLDC	C "News Updat	e" (Flasher) Se	ection			
U U	^Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of WR-SR and ER-SR corridor has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.								
^In case of d	rawl of Karnatak	a beyond 3800 MW,	the voltages in	Bengaluru are	a are observed	to be critically lov	v. This issue may be	e taken care o	f by Karnataka SLDC by taking appropiate measures.
SR-WR TTO	C/ATC figures ha	we been calculated co	onsidering 01 u	nit (800 MW) :	at Kudgi TPS	in service. The figu	ares are subject to c	hange with cl	hange in generation at Kudgi TPS.
WR-NR/Imj	port of NR TTC h	nas been calculated co	onsidering gene	ration at Parico	cha TPS as 350) MW. TTC figure	s are subject to cha	nge with sign	ificant change in generation at Pariccha TPS.

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
		00-06	25400 24450**		24000 23050**	15651 14701**	8349		
		06-09	25400 24450**		24000 23050**	16040 15090**	7960		
NR	1st December 2021 to 31st December 2021	09-17	25400 24450**	1400	24000 23050**	16040 15090**	7960		
		17-18	25400 24450**		24000 23050**	16040 15090**	7960		
		18-24	.8-24 24450**		24000 23050**	15651 14701**	8349		
NER [*]	1st December 2021 to 31st December 2021	00-02 02-07 07-12 12-18 18-22 22-24	810 810 805 820 610 810	45	765 765 760 775 565 765	455 455 455 455 455 455 455	310 310 305 320 110 310		
WR [*]									
SR ^{*#}	1st December 2021 to 31st December 2021	00-06 06-18 18-24	15100 15100 15100	1000	14100 14100 14100	6270 6355 6270	7830 7745 7830		
Bilateral & **Consider ous genera * For appro following r	& First Come First ring 400 kV Rihan tion in Rihand stag oving STOA Bilate ratio: Simultaneous impo TC =B	Serve). Id stage-I ge-III. Rif eral trans	II - Vindhyac hand Stage-II actions, marg	hal PS D/C li I generation is	ne as inter-reg s considered a	gional line for the as NR regional en	purpose of sche tity.	duling, meter	lered for advanced transactions ing and accounting and 950 MW ex- NR Corridor & ER-NR Corridor in th

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

#Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of SR Import has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.

In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka by taking appropriate measures.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments		
		00-06				471	3329				
NR*	1st December 2021 to 31st December 2021	06-18	4500	700	3800	2114	1686				
		18-24				471	3329				
	1st December 2021 to 31st December 2021	00-02	3280	- 45	3235	131	3104				
		02-07	3280		3235	131	3104				
NER*		07-12	3230		45 322	3185	131	3054			
NEK*		12-18	3270			43 3225 3195	3225	131	3094		
		18-22	3240				3195	3195	131	3064	
		22-24	3280		3235	131	3104				
WR*											
SR*^	1st December 2021 to 31st December 2021	00-24	3700	400	3300	1586	1714				

^SR Export TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

Limiting	Constraints (Corridor wise)	
_		Applicable Revisions
Corridor	Constraint	
WR-NR	N-1 contingency of 1000 MVA, 765/400 kV ICT at Orai will overload the other ICT	Rev- 0
	N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit	Rev- 0
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	Rev- 0
ER-NR	Inter-regional flow pattern towards NR	Rev- 0
WR-SR	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT	
	N-1 of one ckt of 765kV Angul-Srikakulam D/C will overload the other circuit	Rev- 0
SK	Low Voltage at Gazuwaka (East) Bus.	
SR-WR	a) N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt b) N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	Rev- 0
ER-NER	 a) N-1 contingency of 400 kV Bongaigaon - Azara line b) High Loading of 220 kV Salakati - BTPS D/C 	Rev- 0
NER-ER	 a) N-1 contingency of 220 kV Salakati - Alipurduar I or II b) High Loading of 220 kV Salakati - Alipurduar II or I 	Rev- 0
W3 zone Injection		Rev- 0

Limiting Constraints (Simultaneous)

g	e onstrumts	(Simultaneous)	Applicable Revisions
		Inter-regional flow pattern towards NR	Rev- 0
NR	Import	N-1 contingency of 1000 MVA, 765/400 kV ICT at Orai will overload the other ICT	Rev- 0
		N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit	Rev- 0
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.	Rev- 0
	Export	(n-1) contingency of 400 kV Saranath-Pusauli	Kev- 0
		a) N-1 contingency of 400 kV Bongaigaon - Killing line (0000 hrs to 2400 hrs)	
	Import	b) High Loading of 220 kV Balipara-Sonabil (0000 hrs to 0700 hrs)	Rev- 0
NER		c) High Loading of 220 kV Salakati - BTPS D/C (0700 hrs to 1200 hrs)	
	F	a) N-1 contingency of 220 kV Salakati - Alipurduar I or II	D 0
	Export	b) High Loading of 220 kV Salakati - Alipurduar II or I	Rev- 0
		N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT	
	Import	N-1 of one ckt of 765kV Angul-Srikakulam D/C will overload the other circuit	Rev- 0
SR	-	Low Voltage at Gazuwaka (East) Bus	
	Evnort	N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt	Rev- 0
	Export	N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	Kev- 0

National Load Despatch Centre Total Transfer Capability for December 2021

Revision	Date of	Period of	Peacon for Pavision/Comment	Convidor Affosted
No	Revision	Revision	Reason for Revision/Comment	Corridor Affected

ASSUN	MPTIONS IN BASECASE						
			21				
S.No.	Name of State/Area		Load	Generation			
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)		
	NORTHERN REGION						
1	Punjab	10744	10867	3971	3971		
2	Haryana	9492	9088	2701	2701		
3	Rajasthan	10485	9635	8259	8259		
4	Delhi	5321	5152	796	795		
5	Uttar Pradesh	20631	20099	10623	10689		
6	Uttarakhand	2124	1886	928	939		
7	Himachal Pradesh	1354	1114	783	769		
8	Jammu & Kashmir	2363	1962	884	883		
9	Chandigarh	313	249	0	0		
10	ISGS/IPPs	48	48	21958	20013		
	Total NR	62875	60100	50903	49019		
II	EASTERN REGION						
1	Bihar	6537	5617	356	349		
2	Jharkhand	1958	1503	511	501		
3	Damodar Valley Corporation	2985	2723	5856	4190		
4	Orissa	4513	4310	3998	3798		
5	West Bengal	9704	8401	7033	6210		
6	Sikkim	119	116	0	0		
7	Bhutan	181	181	2325	2325		
8	ISGS/IPPs	810	810	15771	11533		
	Total ER	26808	23662	35850	28906		
	WESTERN REGION						
1	Maharashtra	17405	16509	11624	10789		
2	Gujarat	13918	11320	8601	7246		
3	Madhya Pradesh	9254	8534	3596	3845		
4	Chattisgarh	4309	3965	2531	2835		
5	Daman and Diu	276	236	0	0		
6	Dadra and Nagar Haveli	744	870	0	0		
7	Goa-WR	534	420	0	0		
8	ISGS/IPPs	1784	3263	36712	32338		
-	Total WR	48224	45117	63064	57053		

IV	SOUTHERN REGION				
1	Andhra Pradesh	8024	7220	6268	5204
2	Telangana	9100	8117	5196	5078
3	Karnataka	8396	6654	6023	4850
4	Tamil Nadu	15210	13068	7256	6376
5	Kerala	3778	2349	1614	961
6	Pondy	264	264	0	0
7	Goa-SR	82	82	0	0
8	ISGS/IPPs	37	37	14805	14794
	Total SR	44891	37791	41162	37263
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	140	95	118	118
2	Assam	1849	1588	615	574
3	Manipur	207	86	105	103
4	Meghalaya	315	255	302	229
5	Mizoram	150	55	60	60
6	Nagaland	173	155	96	93
7	Tripura	435	260	300	300
8	ISGS/IPPs	0	0	2371	2370
	Total NER	3269	2494	3967	3847
	Total All India	186067	169164	194946	176088