# National Load Despatch Centre Total Transfer Capability for January 2013

Issue Date: 20/01/2013 Issue Time: 1115 hrs Revision No.14

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments
NR-WR	1st January 2013 to 31st January 2013	00-24	1500	200	1300	286	1014	
	1st January 2013 to 15th January 2013	00-24	1700	200	1500	780	720	LTA revised due to commisioning of CGPL unit-3
WR-NR	16th January 2013 to 17th January 2013	00-09 18-24	1700	200	1500	780	720	Revised due to Shutdown of 220kV Kota-Badod
	18th January 2013 to	09-18'	1600 1700	200	1400	780	620 720	Total Badou
	31st January 2013	00-24	1700	200	1300	760	720	
	1st January 2013 to	00-17	800	***	600		600	
NR-ER	31st January 2013	23-24 17-23	900	200	700	0	700	
	1st January 2013 to	00-17		200		1770	280	DVC LTA figures to ND included
	3rd January 2013	23-24 17-23	2350	300	2050	1770	280	DVC LTA figures to NR included
	4th January 2012	00-10	2350	200	2050	1770	280	Revised due to emergency shutdown
	4th January 2013	12-24 10-12'	2250	300	1950	1770	180	of 400 KV Kahalgaon - Biharsariff - II
ED MD	5th January 2013 to	00-17	2250	200	2050	1770	280	
ER-NR	17th January 2013	23-24 17-23	2350	300	2050	1770	280	
	18th January 2013  19th January 2013 to	00-11	2350	***	2050	1770	280	Revised due to Emergency shutdown
		19-24 11-19'	1910	300	1610	1610	0	of 400kV Malda-New Purnea-I
		00-17				1770	280	
	31st January 2013	23-24 17-23	2350	300	2050	1770	280	
	1	17 23				1770	200	
	1st January 2012 to 20th January 2012	00-24	1400	300	1100	0	1100	
W3-ER#	21st January 2012	00-07, 18-24	1400	300	1100	0	1100	Revised due to shutdown of 400 kV Sipat-Ranchi D/C
	22-4 I 2012 to	07-18'	1200		900		900	Sipat-Kancin D/C
	22nd January 2012 to 31st January 2012	00-24	1400	300	1100	0	1100	
ER-W3	1st January 2012 to 31st January 2012	00-24	900	250	650	650	0	
WR-SR	1st January 2013 to 31st January 2013	00-24	1000	0	1000	992	8	
SR-WR	1st January 2013 to 31st January 2013	00-24	1000	0	1000	0	1000	
		00-05	920		920		660	David day to full and lability of ED
	1st January 2013 to 7th January 2013	10-19	830	0	830	170	660	Revised due to full availability of ER ISGS, TSTPP st-II and less drawal by
		05-10 19-24	950*		950* 780	780*	Odisha.	
		00-05 17-19	830	0	830	170	660	
	8th January 2013	05-07' 19-24	950*	0	950*	170	780*	Revised due to shutdown of 400 kV Baripada-Kharagpur-Kolaghat.
		07-10'	750*	0	750*	170*	580*	, 5, 5
		10-17' 00-05	750	0	750	170	580	
	9th January 2013 to	10-19	830	0	830	170	660	
ER-SR	12th January 2013	05-10 19-24	950*	0	950*	170	780*	
		00-05	830		830		660	Revised due to shutdown of HVDC
	13th January 2013	05-19'	170	0	170	170	0	Talcher-Kolar Pole 1
		19-24 00-05	950* 830		950* 830		780* 660	n i i i i i i i i i i i i i i i i i i i
	14th Januray 2013	05-19'	0	0	0	170	0	Revised due to shutdown of HVDC Talcher-Kolar Pole 2
		19-24 00-05	950*		950*		780*	
	15d Y 2015	16-19	830	0	830	150	660	Revised due to shutdown of 400 KV
	15th January 2013	07-16' 05-07	750	0	750	170	580	Kolaghat - Baripada
		19-24	950*		950*		780*	
	16th January 2013-	00-05 10-19	830		830	150	660	
	31st January 2013	05-10 19-24	950*	0	950*	170	780*	
SR-ER	1st January 2012 to	00-17 23-24	700	0	700	197	503	
DIV-DIV	31st January 2012	17-23	700	,	700	171	503	1

# National Load Despatch Centre Total Transfer Capability for January 2013

Issue Date: 20/01/2013 Issue Time: 1115 hrs Revision No.14

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments	
	1st January 2013 to	00-17	450	25	415	182	233		
	15th January 2013	23-24 17-23	450	35	415	186	229		
	16th January 2013 to	00-08	450		415	182	233		
	17th January 2013	17-24 08-17'	240	35	205	205	0	1. Revised due to Shutdown of 400	
		00-08						kV Balipara – Bongaigaon II from	
ER-NER	18th January 2013	19-24	450	35	415	182	233	16.01.13 to 19.01.13. 2. Revised due to Emergency	
		08-19' 00-08	240		205	205	0	shutdown of 400kV Malda-New	
	19th January 2013	17-24	450	35	415	182	233	Purnea-I on 18.01.13.	
		08-17'	240		205	205	0		
	20th January 2013 to	00-17 23-24	450	35	415	182	233		
	31st January 2013	17-23	450		415	186	229		
	1st January 2013 to	00-17 23-24	600	100	500	0	500		
	15th January 2013	17-23	300	100	200	Ĭ	200		
	161 X 2012	00-08	600		500		500		
	16th January 2013 to 17th January 2013	23-24 08-17'	100	100	0	0	0		
		17-23	300		200		200	1. Revised due to Shutdown of 400	
	18th January 2013	00-08	600	100	500		500	kV Balipara – Bongaigaon II from 16.01.13 to 19.01.13.	
NER-ER		23-24 08-19'	100		0	0	0	2. Revised due to Emergency shutdown of 400kV Malda-New	
		19-23	300		200		200		
	19th January 2013	00-08 23-24	600	100	500	0	500	Purnea-I on 18.01.13.	
		08-17'	100		0		0		
		17-23	300		200		200		
	20th January 2013 to	00-17 23-24	600	100	500	0	500		
	31st January 2013	17-23	300		200		200		
S1-S2	1st January 2013 to 31st January 2013	00-24	5500	200	5300	4000	1300		
Import of Punjab	1st January 2013 to 31st January 2013	00-24	5400	300	5100	3243	1857		
Import TTC for DD & DNH	1st January 2013 to 31st January 2013	00-24	980	0	980	LTA and MTO.			
	1st January 2013 to 4th January 2013	00-18, 22-24	7000	200	6800	6400	400	6400 MW corresponds to maximum effective LTA from W3. Export Margin from W3 would vary on daily basis as per the Declared	
		18-22	7500		7300		900	Capability (DC) of generators scheduling power on long term basis in the zone.	
		00-08'	8000		7800		1400		
	5th January 2012	08-17'	7500	200	7300	6400	900	Revised due to Commissioning of	
	5th January 2013	17-23'	8000	200	7800	0400	1400	400 kV Raipur-Wardha D/C with	
		23-24	7500		7300		900	40% Series Compensation at Wardha end.	
W3 zone	6th January 2013 to	00-17' 23-24	7500	200	7300	6400	900	2. Shutdown of 765 kV Seoni- Wardha ckt-1 and Seoni-Bina from 05.01.13 to 07.01.13.	
Injection	7th January 2013	17-23'	8000	200	7800	6400	1400	05.01.13 to 07.01.13.	
1	8th January 2013						4.400		
	8th January 2013	00-17, 23-24	8000	200	7800	6400	1400		
	8th January 2013		8000 8500 8000	200	7800 8300 7800	6400	1400 1900 1400		
	8th January 2013 9th January 2013	23-24 17-23 00-08 08-17'	8500 8000 7500	200	8300 7800 7300	6400 6400	1900 1400 900		
		23-24 17-23 00-08 08-17' 17-23	8500 8000 7500 8000		8300 7800 7300 7800		1900 1400 900 1400	Revised due to shutdown of 765 kV	
		23-24 17-23 00-08 08-17'	8500 8000 7500		8300 7800 7300		1900 1400 900 1400 900 900	Seoni-Wardha I from 09.01.13 to	
		23-24 17-23 00-08 08-17' 17-23 23-24 00-17 17-19	8500 8000 7500 8000 7500 7500 8000		8300 7800 7300 7800 7300 7300 7800		1900 1400 900 1400 900 900 1400		
	9th January 2013	23-24 17-23 00-08 08-17' 17-23 23-24 00-17 17-19 19-23	8500 8000 7500 8000 7500 7500 8000 8500	200	8300 7800 7300 7800 7300 7300 7800 8300	6400	1900 1400 900 1400 900 900 900 1400 1900	Seoni-Wardha I from 09.01.13 to	
	9th January 2013	23-24 17-23 00-08 08-17' 17-23 23-24 00-17 17-19	8500 8000 7500 8000 7500 7500 8000	200	8300 7800 7300 7800 7300 7300 7800	6400	1900 1400 900 1400 900 900 1400	Seoni-Wardha I from 09.01.13 to	

# **National Load Despatch Centre**

### **Total Transfer Capability for January 2013**

Issue Time: 1115 hrs Issue Date: 20/01/2013 Revision No.14

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments
----------	------	-------------------------	--	-----------------------	--	--	--	----------

#### **Limiting Constraints**

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Bina(PG)-Bina(MP)
WR-NR	(n-1) contingency of 400 kV Bina-Gwalior
NR-ER	(n-1) contingency of 400 kV Pusauli-Biharsharif
ER-NR	(n-1) contingency of 400 kV Farakka-Malda
W3-ER	(n-1) contingency of 400 kV Farakka-Malda*
ER-W3	High loading of 400 kV Raipur-Bhadrawati T/C, Bhilai-Bhadrawati S/C, Bhilai-Koradi and Bhilai-Seoni* (n-1) contingency of 400kV Rourkela-Jamshedpur
WR-SR	Bhadrawati HVDC B/B link capacity (n-1) Coningency of 400kV Gooty-Somanhalli & 400kV Gooty-Nelamangala l
SR-WR	Bhadrawati HVDC B/B link capacity
ER-SR	(n-1) contingency of 400 kV Rourkela-Talcher* Low Voltage in Chennai Area (n-1) contingency of 400 kV Vijaywada-Nellore*
SR-ER	(n-1) contingency of 400 kV Farakka-Malda* (n-1) contingency of 400 kV Kadappa-Kolar and Neyvelli- Sriperumbudur
ER-NER	(n-1) contingency of 400 kV Farakka-Malda* High Loading of 220 kV BTPS-Agia High Loading of 220 kV Balipara-Samaguri High Loading of 400/220 kV 315 MVA ICT at Misa, Balipara
NER-ER	(n-1) contingency of 400 kV Binaguri-Bongaigaon High loading of 132 kV LTPS - Mariani*
S1-S2	(n-1) contingency of 400 kV Hosur-Salem
Import of Punjab	(n-1) contingency of ICT at Moga
W3 zone export TTC	(n-1) contingency of $400~\rm kV$ Raipur-Wardha and High loading of $400~\rm kV$ Bhilai-Koradi

<sup>\*</sup>Primary constraints

ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam
 St comprises of AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Pondicherry
 Wa comprises of the following regional entities and would be operational wef 0000 hrs of 18th September 2012
 Chattisgarh, b) Jindal Power Limited (JPL), c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
 BALCO, g) Sterlite (#1,3,4), b) NSPCL, j) Korba, j) Sipat
 \* additional 250 MW can be transferred to SR if injection point is South Odisha

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments
ER								
	1st January 2013 to 3rd January 2013	00-17 23-24 17-23	4050	500	3550 3550	2550 2550	1000	LTA revised due to commissioning of CGPL unit-3
	4th January 2013	00-17 23-24 17-23	4050 3950	500	3550 3450	2550 2550	1000	Revised due to emergency shutdown of 400 KV Kahalgaon - Biharsariff - II
NR	5th January 2013 to 15th January 2013	00-17 23-24 17-23	4050	500	3550 3550	2550 2550	1000	
NK	16tth January 2013 to 17th January 2013	00-09 18-24 09-18'	4050 3950	500	3550 3450	2550	1000	Revised due to Shutdown of 220kV Kota-Badod
	18th January 2013	00-11 19-24 11-19'	4050 3610	500	3550 3110	2550 2550	1000 560	Revised due to Emergency shutdown of 400kV Malda- New Purnea-I
	19th January 2013 to 31st January 2013	00-17 23-24 17-23	4050	500	3550 3550	2550 2550	1000	
	1st January 2013 to 15th January 2013	00-17 23-24 17-23	450 450	35	415 415	182 186	233 229	
	16th January 2013 to 17th January 2013	00-08 17-24 08-17'	450 240	35	415 205	182 205	233	Revised due to Shutdown     of 400 kV Balipara –
NER	18th January 2013	00-08 17-24 08-19'	450 240	35	415 205	182 205	233	Bongaigaon II from 16.01.13 to 19.01.13.  2. Revised due to Emergency
	19th January 2013	00-08 17-24 08-17'	450 240	35	415 205	182 205	233	shutdown of 400kV Malda- New Purnea-I on 18.01.13.
	20th January 2013 to 31st January 2013	00-17 23-24 17-23	450 450	35	415 415	182 186	233 229	
WR								
	1st January 2013 to 7th January 2013	00-05 10-19 05-10	1830	0	1830	1162	668	
		19-24 00-05 17-19	1950* 1830	0	1950* 1830		788* 668	Revised due to shutdown of
	8th January 2013	05-07' 19-24 07-10'	1950* 1750*		1950* 1750*	1162	788* 588*	400 kV Baripada-Kharagpur- Kolaghat.
	9th January 2013 to 12th January 2013	10-17' 00-05 10-19	1750 1830	0	1750 1830	1162	588 668	
SR	13th January 2013	05-10 19-24 00-05 05-19'	1950* 1830 1170	0	1950* 1830 1170	1162	788* 668 8	Revised due to shutdown of HVDC Talcher-Kolar Pole 1
	14th Januray 2013	19-24 00-05 05-19'	1950* 1830 0	0	1950* 1830 0	1162	788* 668 0	Revised due to shutdown of HVDC Talcher-Kolar Pole 2
	15th January 2013	19-24 00-05 16-19 07-16' 05-07	1950* 1830 1750	0	1950* 1830 1750	1162	788* 668 588	Revised due to shutdown of 400 KV Kolaghat - Baripada
	16th January 2013-31st	19-24 00-05 10-19	1950* 1830	0	1950*	1162	788* 668	
	January 2013	05-10 19-24	1950*	1950*		1950*		

<sup>\*</sup> additional 250 MW can be transferred to SR if injection point is South Odisha

# Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments
ER-NR + ER-NER	1st January 2013 to 31st January 2013	00-17 23-24	2700	350	2350	1395	955	
EKILEK	,	17-23	2700		2350	1397	953	
NR	1st January 2013 to 31st January 2013	00-24	2300	500	1800	286	1514	
	1st January 2013 to 15th January 2013	00-17 23-24	600	100	500	0	500	
	15th January 2015	17-23	300		200		200	
	16th January 2013 to 17th January 2013	00-08 23-24	600	100	500	0	500	
		08-17'	100		0		0	1.5. 1.1 . 61 .1
		17-23	300		200		200	1. Revised due to Shutdown of 400 kV Balipara –
NER	18th January 2013	00-08 23-24	600	100	500	0	500	Bongaigaon II from 16.01.13 to 19.01.13.
NEK		08-19'	100		0		0	2. Revised due to Emergency
		19-23	300		200		200	shutdown of 400kV Malda-
	19th January 2013	00-08 23-24	600	100	500	0	500	New Purnea-I on 18.01.13.
		08-17'	100	100	0		0	
		17-23	300		200		200	
	20th January 2013 to	00-17 23-24	600	100	500	0	500	
	31st January 2013	17-23	300		200		200	
WR								
****								
SR	1st January 2013 to 31st January 2013	00-17 23-24	1700	0	1700	197	1503	
	518t January 2015	17-23	1700		1700		1503	

# **Limiting Constraints**

NR	Import	(n-1) contingency of 400 kV Farakka-Malda*
		(n-1) contingency of 400 kV Bina-Gwalior*
	Export	(n-1) contingency of 400 kV Pusauli-Biharsharif
NER	Import	High Loading of 220 kV BTPS-Agia
		High Loading of 220 kV Balipara-Samaguri
		High Loading of 400/220 kV 315 MVA ICT at Misa*
		(n-1) contingency of 400 kV Farakka-Malda*
	Export	High loading of 132 kV LTPS - Marian
		(n-1) contingency of 400 kV Binaguri-Bongaigaon*
SR	Import	(n-1) Coningency of 400kV Gooty-Somanhalli & 400kV Gooty-Nelamangala l
		(n-1) contingency of 400 kV Rourkela-Talcher*
		Low Voltage in Chennai Area
		(n-1) contingency of 400 kV Vijaywada-Nellore
	Export	(n-1) contingency of Chandrapur-Parli
		(n-1) contingency of 400 kV Maithon Kahalgaon
		(n-1) contingency of 400 kV Kadappa-Kolar and Neyvelli- Sriperumbudur
ER-NR + ER-NER	Export	(n-1) contingency of 400 kV Farakka-Malda*

# **ASSUMPTIONS IN BASECASE**

		Loa	ad	Generation		
S.No.	Name of State/Area	Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)	
I	NORTHERN REGION					
1	Punjab	5260	3870	2340	220	
2	Haryana	5160	4690	3430	343	
3	Rajasthan	7310	6600	3980	395	
4	Delhi	4060	3400	1420	142	
5	Uttar Pradesh	10550	9300	5310	522	
6	Jammu & Kashmir	1990	1400	310	25	
7	Uttarakhand	1330	1100	500	28	
8	Himachal Pradesh	1060	970	250	15	
9	Chandigarh	250	100	0		
10	ISGS			15860	1057	
	Total NR	36970	31430	33400	2747	
II	EASTERN REGION					
1	West Bengal	5300	4150	4600	395	
2	Jharkhand	900	850	390	39	
3	Orissa	3000	2500	2800	209	
4	Bihar	1500	1300	130	13	
5	Damodar Valley Corporation	2200	1900	1550	155	
6	Sikkim	60	60	0	100	
7	Bhutan	110	110	1400	140	
8	ISGS	110	110			
	Total ER	13070	10870	6300 <b>17170</b>	590 <b>1541</b>	
	TOTAL ER	13070	10070	17170	1341	
III	WESTERN REGION					
1	Chattisgarh	2770	2140	2520	199	
2	Madhya Pradesh	7650	6230	3440	280	
3	Maharashtra	15660	11910	13110	945	
4	Gujarat	9910	7880	9930	756	
5	Goa	330	200	9930	730	
6	Daman and Diu	220	160			
7	Dadra and Nagar Haveli	530	240			
8	ISGS	530	240	13260	1170	
0						
	Total WR	37070	28760	42260	3350	
IV	SOUTHERN REGION					
		40400	0.450	=000		
1	Andhra Pradesh	10480	9150	7830	588	
2	Tamil Nadu	10120	8950	4960	380	
3	Karnataka	7640	6100	4500	344	
4	Kerala	3240	2420	900	58	
5	Pondy	300	240			
6	Goa	80	80			
7	ISGS			11520	1130	
	Total SR	31860	26940	29710	2500	
٧	NORTH-EASTERN REGION					
1	Manipur	100	60	0		
2	Meghalaya	280	170	110	7	
3	Mizoram	70	40	10	1	
4	Nagaland	80	60	10	1	
5	Assam	880	570	270	22	
6	Tripura	210	150	100	9	
U	Arunachal Pradesh	100	30	0		
7	Aluliaciiai Flaucoli	100	301			
	ISGS			820		
7		0 1720	0		42 <b>82</b>	