National Load Despatch Centre Total Transfer Capability for March 2013

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments	
	1st March 2013 to 5th March 2013	00-24	1500	200	1300	286	1014		
	6th March 2013	00-07, 19-24	1500	200	1300	286	1014	Revised due to shutdown of 400 kV Zerda-Kankroli on 06.03.13.	
		07-19'	1300		1100		814		
NR-WR#	7th March 2013 to 8th March 2013	00-24	1500	200	1300	286	1014	Revised due to Cancellation of 400 kV Zerda-Bhinmal shutdown on 07.03.13.	
		00-04	1500		1300		1014	Revised due to upgradation work of	
	9th March 2013	04-24'	1300	200	1100	286	814	Agra-Gwalior-Bina. The upgradation work would be carried	
	10th March 2013 to 25th March 2013	00-24	1300	200	1100	286	814	out in different stages from 9th March to 25th March 2013	
	26th March 2013 to 31st March 2013	00-24	1500	200	1300	286	1014		
	1st March 2013 to 5th March 2013	00-24	2000	200	1800	1040	760	Review and dynamic studies carried out to reassess transfer capability	
	6th March 2013	00-07, 19-24	2000	200	1800	1040	760	Revised due to shutdown of 400 kV	
	our march 2015	07-19'	1800	200	1600	1040	560	Zerda-Kankroli on 06.03.13.	
WR-NR#	7th March 2013 to 8th March 2013	00-24	2000	200	1800	1040	760	Revised due to Cancellation of 400 kV Zerda-Bhinmal shutdown on 07.03.13.	
	9th March 2013	00-04	2000		1800	1040	760	Revised due to upgradation work of	
		04-24'	1500	200	1300		260	Agra-Gwalior-Bina. The upgradation work would be carried	
	10th March 2013 to 25th March 2013	00-24	1500	200	1300	1040	260	out in different stages from 9th March to 25th March 2013	
	26th March 2013 to 31st March 2013	00-24	2000	200	1800	1040	760		
	1	00-17				T T			
NR-ER	1st March 2013 to 31st March 2013	23-24	900	200	600 700	0	600 700		
	1st March 2013 to 4th	00-17	900		700	1000			
	March 2013	23-24 17-23	2500	300	2200	1900 1900	300		
	5th March 2013	00-09	2500	300	2200	1900	300		
ER-NR	6th March 2013	09-24' 00-24	2200 2200	300	1900 1900	1900	0		
EK-IVK		00-24	2200		1900		0	Revised due to shutdown of 400 kV	
	7th March 2013	18-24	2500	300	2200	1900	300	Kahalgaon-Biharsharif I	
	8th March 2013 to	00-17 23-24	2500	300	2200	1900	300		
	31st March 2013	17-23	2300	300	2200	1900	300		
W3-ER	1st March 2013 to 31st March 2013	00-24	1400	300	1100	0	1100		
ER-W3	1st March 2013 to 31st March 2013	00-24	1000	300	700	650	50		
WR-SR	1st March 2013 to 31st March 2013	00-24	1000	0	1000	992	8		
SR-WR	1st March 2013 to 31st March 2013	00-24	1000	0	1000	0	1000		
		00-05							
ER-SR	1st March 2013 to	10-19	950	0	950	170	780		
21.01	31st March 2013	05-10 19-24	950*		950*		780*	Review of TTC due to change in load generation scenario	
SR-ER	1st March 2013 to	00-17 23-24	700	0	700	197	503		
	31st March 2013	17-23	700		700		503		

National Load Despatch Centre Total Transfer Capability for March 2013

Issue Date: 08/03/2013 Issue Time: 1200 hrs Revision No. 10

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments
ER-NER	1st March 2013 to 31st March 2013	00-17 23-24	400	35	365	228	137	
	51st March 2015	17-23	400		365	228	137	
NER-ER	1st March 2013 to 31st March 2013	00-17 23-24	510	100	410	0	410	
		17-23	280		180		180	
S1-S2	1st March 2013 to 31st March 2013	00-24	5800	200	5600	4400	1200	
Import of Punjab	1st March 2013 to 31st March 2013	00-24	5400	300	5100	3243	1857	
Import TTC for DD & DNH	1st March 2013 to 31st March 2013	00-24	980	0	980	LTA and MTO		
W3 zone Injection	1st March 2013 to 31st March 2013	00-17, 23-24	8000	200	7800	6413	1207	6413 MW corresponds to maximum effective LTA from W3. Export
		17-23	8500	200	8300		1887	Margin from W3 would vary as per the maintenance schedule of generators in the zone.

¹⁾ ER-SR TTC declared at Talcher Interconnector and Gazuwaka HVDC B/B seam

Limiting Constraints

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Bina(PG)-Bina(MP)
WR-NR	(n-1) contingency of 400 kV Bina-Satna leading to high loading of 765/400 kV Bina transformer
NR-ER	(n-1) contingency of 400 kV Pusauli-Biharsharif
ER-NR	(n-1) contingency of 400 kV Farakka-Malda
W3-ER	(n-1) contingency of 400 kV Sterlite-Rourkela
ER-W3	High loading of 400 kV Raipur-Wardha, Raipur-Bhadrawati T/C, Bhilai-Bhadrawati S/C, Bhilai-Koradi and Bhilai-Seoni* (n-1) contingency of 400kV Rourkela-Raigarh
WR-SR	Bhadrawati HVDC B/B link capacity
SR-WR	Bhadrawati HVDC B/B link capacity
ER-SR	(n-1) contingency of 400 kV Vijaywada-Nellore* Low Voltage in Chennai Area (n-1) contingency of 400 kV Rourkela-Talcher*
SR-ER	(n-1) contingency of 400 kV Farakka-Malda* (n-1) contingency of 400 kV Kadappa-Kolar and Neyvelli- Sriperumbudur
ER-NER	(n-1) contingency of 400 kV Farakka-Malda* High Loading of 220 kV BTPS-Agia (n-1) contingency of 400 kV Balipara – Bongaigaon-I
NER-ER	(n-1) contingency of 400 kV Balipara-Bongaigaon-I (n-1) contingency of 220 kV Samaguri – Saruajai I*
S1-S2	(n-1) contingency of 400 kV Hosur-Salem D/C line
Import of Punjab	(n-1) contingency of ICT at Moga
W3 zone export TTC	(n-1) contingency of 400 kV Raipur-Wardha and High loading of 400 kV Bhilai-Koradi

^{*}Primary constraints

¹⁾ ER-SR 11C declared at Taicher Interconnector and Gazdwaka HVDC B/B seam
2) ^ S1 comprises of AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Pondicherry
3) W3 comprises of the following regional entities and would be operational wef 0000 hrs of 18th September 2012
a) Chattisgarh, b) Jindal Power Limited (JPL), c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat
* additional 250 MW can be transferred to SR if injection point is South Odisha

Simultaneous Import Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments
ER								
	1st March 2013 to 4th March 2013	00-17 23-24	4500	500	4000	2940	1060	Review and dynamic studies carried out to reassess transfer
	5th March 2013	17-23 00-09 09-24'	4500 4200	500	4000 4000 3700	2940 2940	1060 1060 760	capability 1. Revised due to shutdown of 400 kV Kahalgaon-
	6th March 2013	00-07, 19-24	4200	500	3700	2940	760	Biharsharif I. 2.Shutdown of 400 kV Zerda-
		07-19'	4000		3500		560	Kankroli on 06.03.13.
NR#	7th March 2013	00-18'	4200	500	3700	2940	760	3.Revised due to Cancellation of 400 kV Zerda-Bhinmal
1111		18-24'	4500		4000		1060	shutdown on 07.03.13.
	8th March 2013	00-24	4500	500	4000	2940	1060	Revised due to upgradation work of Agra-Gwalior-Bina.
	9th March 2013	00-04	4500		4000		1060	The upgradation work would
		04-24'	4000		3500		560	be carried out in different
	10th March 2013 to 25th March 2013	00-24	4000		3500		560	stages from 9th March to 25th March 2013
	26th March 2013 to 31st March 2013	00-17 23-24	4500	500	4000	2940	1060	Review and dynamic studies carried out to reassess transfer
	51st Maich 2015	17-23			4000	2940	1060	capability
NER	1st March 2013 to 31st March 2013	00-17 23-24	400	35	365	228	137	
	51st March 2015	17-23	400		365	228	137	
WR								
SR	1st March 2013 to	00-05 10-19	1950	0	1950	1162	788	
SK	31st March 2013	05-10 19-24	1950*	0	1950*		788*	Review of TTC due to change load generation scenario

Simultaneous Export Capability

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Comments
ER-NR + ER-NER	1st March 2013 to 31st March 2013	00-17 23-24	2700	350	2350	2132	218	
EK-NEK		17-23	2700		2350	2132	218	
	1st March 2013 to 31st March 2013	00-17 23-24	2300	200	2100	286	1814	
	518t Wiaicii 2015	17-23	2400		2200		1914	
		00-07 23-24	2300		2100		1814	Revised due to Shutdown of 400
	6th March 2013	07-17'	2100	200	1900	286	1614	kV Zerda-Kankroli on 06.03.13 & 400 kV Zerda-Bhinmal on
		17-19	2200		2000		1714	7.03.13.
		19-23'	2400		2200		1914	7.03.13.
	7th March 2013 to 8th March 2013	00-17 23-24	2300	200	2100	286	1814	Revised due to Cancellation of 400 kV Zerda-Bhinmal shutdown
NR#		17-23	2400		2200		1914	on 07.03.13.
	9th March 2013	00-04	2300	200	2100	286	1814	Revised due to upgradation work
		04-17 23-24	2100		1900		1614	of Agra-Gwalior-Bina. The upgradation work
		17-23	2200		2000		1714	carried out in different stages
	10th March 2013 to 25th March 2013	00-17 23-24	2100	200	1900	286	1614	from 9th March to 25th March
	23th Maich 2013	17-23	2200		2000		1714	2013
	26th March 2013 to 31st March 2013	00-17 23-24	2300	200	2100	286	1814	
		17-23	2400		2200		1914	
NER	1st March 2013 to 31st March 2013	00-17 23-24	510	100	410	0	410	
		17-23	280		180		180	
WR								
		00.4						
SR	1st March 2013 to 31st March 2013	00-17 23-24	1700	0	1700	197	1503	
	51St March 2013	17-23	1700		1700		1503	

 $[\]ensuremath{^*}$ additional 250 MW can be transferred to SR if injection point is South Odisha

Limiting Constraints

NR	Import	(n-1) contingency of 400 kV Farakka-Malda*					
		(n-1) contingency of 400 kV Bina-Satna leading to high loading of 765/400 kV Bina transformers*					
	Export	(n-1) contingency of 400kV Bina(PG)-Bina(MP)					
		(n-1) contingency of 400 kV Pusauli-Biharsharif					
NER	Import	High Loading of 220 kV BTPS-Agia					
		(n-1) contingency of 400 kV Balipara – Bongaigaon-I					
		(n-1) contingency of 400 kV Farakka-Malda*					
	Export	(n-1) contingency of 220 kV Samaguri – Saruajai I*					
		(n-1) contingency of 400 kV Balipara-Bongaigaon-I					
SR	Import	(n-1) Coningency of 400kV Gooty-Somanhalli & 400kV Gooty-Nelamangala line					
		(n-1) contingency of 400 kV Rourkela-Talcher*					
		Bhadrawati HVDC B/B link capacity					
		(n-1) contingency of 400 kV Vijaywada-Nellore					
	Export	(n-1) contingency of 400 kV Farakka-Malda					
		(n-1) contingency of 400 kV Maithon-Kahalgaon					
		(n-1) contingency of 400 kV Kadappa-Kolar and Neyvelli- Sriperumbudur					
ER-NR + ER-NER	Export	(n-1) contingency of 400 kV Farakka-Malda*					

ASSUMPTIONS IN BASECASE

		Lo	ad	Generation		
S.No.	Name of State/Area	Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)	
ı	NORTHERN REGION					
1	Punjab	5678	4250	2437	2318	
2	Haryana	5592	4591	3623	3623	
3	Rajasthan	7243	6793	4084	4089	
4	Delhi	4090	3299	1206	1206	
5	Uttar Pradesh	10774	9516	6020	5839	
6	Jammu & Kashmir	1800	1359	333	339	
7	Uttarakhand	1365	1100	523	302	
8	Himachal Pradesh	1043	959	218	131	
9	Chandigarh ISGS	188	86	0 16384	11062	
10		07770	04050			
	Total NR	37773	31952	34828	28910	
	EASTERN REGION					
1	West Bengal	0457	5.450	4744	4000	
2	Jharkhand	6457	5456	4744	4088	
3	Orissa	964	650	354	354	
4	Bihar	3009	2300	1710	1611	
5	Damodar Valley Corporation	1805	1450	101	101	
6	Sikkim	2303	2000 44	2954 0	<u>2954</u> 0	
7	Bhutan	112	112	245	245	
8	ISGS	112	112	6505	5995	
	Total ER	14694	12012	16613	15348	
	Total Lit	14034	12012	10010	10040	
III	WESTERN REGION					
1	Chattisgarh	3153	2242	2518	2025	
2	Madhya Pradesh	7200	5146	3443	2802	
3	Maharashtra	15717	13582	13113	9454	
4	Gujarat	10497	8800	9933	7564	
5	Goa	420	280			
6	Daman and Diu	252	190			
7	Dadra and Nagar Haveli	602	504			
8	ISGS			11920	11796	
	Total WR	37841	30744	40927	33641	
IV	SOUTHERN REGION					
1	Andhra Pradesh	10835	9993	8217	6817	
2	Tamil Nadu	10456	8310	5148	4619	
3	Karnataka	8521	7469	5482	4397	
4	Kerala	3314	2209	2248	645	
5	Pondy	320	231			
6	Goa	84	84			
7	ISGS			10955	10772	
	Total SR	33530	28296	32050	27250	
	NORTH-EASTERN REGION					
1	Manipur	100	70	0	0	
2	Meghalaya	280	196	99	71	
3	Mizoram	70	49	4	3	
4	Nagaland	110	77	11	10	
5	Assam	1230	840	222	203	
6	Tripura	221	155	94	91	
7	Arunachal Pradesh	105	74	0	400	
8	ISGS Total NER	0	1461	934	499	
	TOTAL NEIN	2116	1461	1364	877	
	Total All India	125954	104465	125782	106026	