					atch Centr lity for Octo				
Issue Date:	8th October, 2	021	Issu	e Time: 170	0 hrs		Re	vision No.	12
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
	1st October	00-06				378	1622		
NR-WR*	2021 to 31st October 2021	06-18	2500	500	2000	956	1044		
		18-24				378 11362	1622		
		00-06	19500	1000	18500	10412**	7138		
	1.0.1		18550**		17550**				
WR-NR*	1st October 2021 to 7th	06-18	19500	1000	18500	11751	6749		
	October 2021		18550** 19500		17550** 18500	10801** 11362			
		18-24	18550**	1000	17550**	10412**	7138		
		00-06	19500	1000	18500	11362	7138		
		00-00	18550**	1000	17550**	10412**	/130		
		06-08	19500	1000	18500	11751	6749		
WR-NR*	8th October 2021		18550** 18700		17550** 17700	10801** 11751			
		08-18	17750**	1000	16750**	10801**	5949		
			18700		17700	11362			
		18-24	17750**	1000	16750**	10412**	6338		
			19500		18500	11362			
		00-06	18550**	1000	17550**	10412**	7138		
	9th October 2021	04.40	19500	1000	18500	11751	<b>17</b> 10		
WR-NR*		06-10	18550**	1000	17550**	10801**	6749		
		10-18	18650	1000	17650	11751	5899		
			17700** 18650	16700** 17650	10801** 11362				
		18-24	17700**	1000	16700**	10412**	6288		
		22.07	19500	1000	18500	11362	5100		
		00-06	18550**	1000	17550**	10412**	7138		
WR-NR*	10th October 2021 to 31st	06-18	19500	1000	18500	11751	6749		
	October 2021		18550**		17550**	10801** 11362			
		18-24	19500	1000	18500	10412**	7138		
			18550**		17550**				
ND ED#	1st October	00-06	2000	200	1800	93	1707		
NR-ER*	2021 to 31st October 2021	06-18 18-24	2000 2000	200	1800 1800	1458 93	342 1707		
ER-NR*	1st October 2021 to 7th October 2021	00-24	5900	400	5500	4372	1128		
	8th October	00-08	5900	400	5500	4372	1128		
ER-NR*	2021	08-24	5600	400	5200	4372	828		
ER-NR*	9th October	00-10	5900	400	5500	4372	1128		
EA-IVK*	2021	10-24	5600	400	5200	4372	828		
ER-NR*	10th October 2021 to 31st October 2021	00-24	5900	400	5500	4372	1128		
W3-ER	1st October 2021 to 31st October 2021	00-24						No limit is	being specified.

					atch Centr lity for Octo				
Issue Date:	8th October, 2	2021	Issu	e Time: 170	0 hrs		Re	vision No.	12
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER-W3	1st October 2021 to 31st October 2021	00-24						No limit is	s being specified.
	1st October	00-05	10000		9350		5470		
WR-SR <sup>^</sup>	2021 to 5th	05-22	10000	650	9350	3880	5470		
	October 2021	22-24	10000		9350		5470		
^	6th October	00-0830	10000	(50)	9350	2000	5470		
WR-SR	2021	0830-22 22-24	9450 9450	650	8800 8800	3880	4920 4920		
	7th October	00-05	10000		9350		5470		
WR-SR <sup>^</sup>	2021 to 8th	05-22	10000	650	9350	3880	5470		
	October 2021	22-24	10000		9350		5470		
wp cp^	9th October	00-05	9100	650	8450	2000	4570		
WR-SR <sup>^</sup>	2021	05-22 22-24	9100 9100	650	8450 8450	3880	4570 4570		
		00-05	10000		9350		5470		
		05-09	10000		9350		5470		
WR-SR <sup>^</sup>	10th October	09-11	7400	650	6750	3880	2870	-2600	TTC/ATC Curtailed to Facilitate Testing of HVDC Raigarh - Pugalur
	2021	11-16 16-22	5200 10000		4550 9350		670 5470	-4800	
		22-24	10000		9350		5470		
	11th October	00-05	10350		9700		5820		
WR-SR	2021 to 31st	05-22	10350	650	9700	3880	5820		
	October 2021	22-24	10350	100	9700	00.4	5820		
	1st October	00-09 09-16	6000 5100	400 400	5600 4700	884 884	4716 3816		•
SR-WR*	2021 to 31st October 2021	16-24	6000	400	5600	884	4716		
	1st October	00-06				2672	2728		
ER-SR <sup>△</sup>	2021 to 8th	06-18	5750	350	5400	2757	2643		
	October 2021	18-24				2672	2728		
	9th October	00-06				2672	2578		
ER-SR <sup>▲</sup>	2021	06-18	5600	350	5250	2757	2493		
		18-24				2672	2578		
		00-06				2672	2728		
ER-SR <sup>△</sup>	10th October 2021	06-18	5750	350	5400	2757	2643		
	2021	18-24				2672	2728		
		00-06				2672	2778		
ER-SR <sup>▲</sup>	11th October 2021 to 31st	06-18	5800	350	5450	2757	2693		
ER-SK	October 2021		5000	550	5450				
	1st October	18-24				2672	2778		
SR-ER *	2021 to 31st	00-24						No limit is	s being Specified.
	October 2021								
		00-02	1680		1635	455	1180		
	1st October	02-07	1680		1635	455	1180		
ER-NER*	2021 to 31st	07-12	1680	45	1635 1635	455	1180		
	October 2021	12-18 18-22	1680 1400		1635	455 455	1180 900		
		22-24	1680		1635	455	1180		
		00-02	2950		2905	81	2824		
	1st October	02-07 07-12	2950 2950		2905 2905	81 81	2824 2824		
NER-ER*	2021 to 31st	12-18	2950	45	2905	81	2824		
	October 2021	18-22	2850		2805	81	2724		
		22-24	2950		2905	81	2824		
W3 zone Injection	1st October 2021 to 31st October 2021	00-24	No limit is be	ing specified (In	n case of any co	onstraints appearir	g in the system, W3	zone export	would be revised accordingly)
Note: TTC/A	ATC of S1-(S2&	S3) corridor, Import	of S3(Kerala)	, Import of Pu	injab and Imp	ort of DD & DNH	is uploaded on NI	LDC website	e under Intra-Regional Section in Monthly ATC.
							-		

			National I Total Trans	1	atch Centr ity for Octo				
Issue Date: 8th October, 2021			Issu	e Time: 1700	) hrs		Re	12	
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
* Fifty Percen	t (50 % ) Count	er flow benefit on acco	unt of LTA/M	FOA transactio	ns in the revers	e direction would	be considered for ad	vanced transa	actions (Bilateral & First Come First Serve).
**Considering regional entity		stage-III - Vindhyach	al PS D/C line	as inter-regiona	l line for the p	urpose of scheduli	ng, metering and acc	ounting and 9	50 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR
f) BALCO, g) and any other r # The figure is Fuel shortage/ In the eventua In case of TTO 1) The TTC	Sterlite (#1,3,4), regional entity ge s based on LTA/ New units being lity that net sche C Revision due t value will be rev	b) Jindal Power Limited h) NSPCL, i) Korba, j) nerator in Chhattisgarh MTOA approved by C commissionned the L dules exceed ATC, rea o any shutdown : ised to normal values a ised to normal values i	Sipat, k) KSK CTU and Alloca TA/MTOA uti al time curtailm	Mahanadi, L)D ation figures as lized would va- ents might be e	B Power, m) KV per RPCs RTA y. RLDC/NLI ffected by RLI	WPCL, n)Vandana A/REA. In actual ( DC would factor th DCs/NLDC.	Vidyut o)RKM, p)Gl	MR Raikheda, its being on N	q)Ind Barath
Real Time TT	C/ATC revision	s are uploaded on POS	SOCO/NLDC "	News Update"	(Flasher) Secti	on			
Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of WR-SR and ER-SR corridor has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.									
^In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka SLDC by taking appropriate measures.									
SR-WR TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.									

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

Simultane	ous Import Capal	bility								
Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
		00-06 24450**		24000 23050**	15734 14784**	8266				
	1st October 2021 to 7th October 2021	06-09	25400 24450**		24000 23050**	16123 15173**	7877			
NR		to 7th October	to 7th October	09-17 25400 24450**	1400	24000 23050**	16123 15173**	7877		
		17-18 24450**		24000 23050**	16123 15173**	7877				
		18-24	25400 24450**		24000 23050**	15734 14784**	8266			
		00-06	25400 24450**		24000 23050**	15734 14784**	8266			
		06-08	25400 24450**		24000 23050**	16123 15173**	7877			
		08-09	24300 23350**		22900 21950**	16123 15173**	6777			
NR	8th October 2021	09-17	24300 23350**	1400	22900 21950**	16123 15173**	6777			
		17-18	24300 23350**		22900 21950**	16123 15173**	6777			
		18-24	24300 23350**		22900 21950**	15734 14784**	7166			

1			25400		24000	15724	[	
		00-06	25400		24000	15734	8266	
		00 00	24450**		23050**	14784**	0200	
			25400		24000	16123		
		06-09					7877	
			24450**		23050**	15173**		
			25400		24000	16123		
		09-10	24450**		23050**	15173**	7877	
NR	9th October		24430**	1400	23030**	13173**		
	2021		24250	1400	22850	16123		
		10-17					6727	
			23300**		21900**	15173**		
		17-18	24250		22850	16123		
			21230		22030	10125	6727	
			23300**		21900**	15173**		
		18-24	24250		22850	15734	7116	
		10 21	23300**		21900**	14784**	/110	
			25400		24000	15734		
		00-06	24450**		23050**	14784**	8266	
			25400		24000	16123		
	10th October	06-09	23400		24000	10125	7877	
		2			23050**	15173**		
NR	2021 to 31st	09-17	25400	1400	24000	16123	7877	
	October 2021	0, 1,	24450**		23050**	15173**	1011	
		17-18	25400		24000	16123	7877	
		17-10	24450**		23050**	15173**		
			25400		24000	15734		
		18-24	24450**		23050**	14784**	8266	
		00-02	1180		1135	455	680	
	1st October 2021	02-07	1180		1135	455	680	
NER <sup>*</sup>	to 31st October	07-12	1180	45	1135	455	680	
	2021	12-18 18-22	1180 900		1135 855	455 455	680 400	
		22-24	1180		1135	455	680	
WR <sup>*</sup>								
		00-06	15750		14750	6553	8197	
	1st October 2021 to 5th October							
SR <sup>*#</sup>		06-18	15750	1000	14750	6638	8112	
5K	2021			1000				
		10.24	16750		14750	6550	0107	
		18-24	15750		14750	6553	8197	

	-					-			
		00-06	15750		14750	6553	8197		
		06-0830	15750		14750	6638	8112		
SR <sup>*#</sup>	6th October 2021	0830-18	15200	1000	14200	6638	7562		
		18-24	15200		14200	6553	7647		
		00-06	15750		14750	6553	8197		
SR <sup>*#</sup>	7th October 2021 to 8th October 2021	06-18	15750	1000	14750	6638	8112		
		18-24	15750		14750	6553	8197		
		00-06	14700		13700	6553	7147		
SR <sup>*#</sup>	9th October 2021	06-18	14700	1000	13700	6638	7062		
		18-24	14700		13700	6553	7147		
		00-06	15750		14750	6553	8197		
		06-09	15750		14750	6638	8112		
	10th October	09-11	13150		12150	6638	5512	-2600	TTC/ATC Curtailed to Facilitate Testing of
SR <sup>*#</sup>	2021	11-16	10950	1000	9950	6638	3312	-4800	HVDC Raigarh - Pugalur
		16-18	15750		14750	6638	8112		
		18-24	15750		14750	6553	8197		
		00-06	16150		15150	6553	8597		
SR <sup>*#</sup>	11th October 2021 to 31st October 2021	06-18	16150	1000	15150	6638	8512		
		18-24	16150		15150	6553	8597		

\* Fifty Percent (50 %) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

\*\*Considering 400 kV Rihand stage-III - Vindhyachal PS D/C line as inter-regional line for the purpose of scheduling, metering and accounting and 950 MW ex-bus generation in Rihand stage-III. Rihand Stage-III generation is considered as NR regional entity.

\* For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

Margin in Simultaneous import of NR = A WR-NR ATC =B ER-NR ATC = C

Margin for WR-NR applicants = A \* B/(B+C)Margin for ER-NR Applicants = A \* C/(B+C)

Real Time TTC/ATC revisions are uploaded on POSOCO/NLDC "News Update" (Flasher) Section

#Though 2X315 MVA, 400/220 kV ICTs at Maradam are N-1 non-compliant, the TTC of SR Import has not been restricted due to the same considering that this aspect will be managed by AP SLDC through appropriate measures like SPS implementation.

In case of drawl of Karnataka beyond 3800 MW, the voltages in Bengaluru area are observed to be critically low. This issue may be taken care of by Karnataka by taking appropriate measures.

WR-NR/Import of NR TTC has been calculated considering generation at Pariccha TPS as 350 MW. TTC figures are subject to change with significant change in generation at Pariccha TPS.

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments								
		00-06				471	3329										
NR*	1st October 2021 to 31st October 2021	06-18	4500	700	3800	2414	1386										
	18-24				471	3329											
		00-02	3450		3405	81	3324										
	1st October 2021 to 31st	02-07	3450	45	3405	81	3324										
NER*		07-12	3450		45	45	45	3405	81	3324							
NEK.	October 2021	12-18	3450					45	45	-	-	3405	81	3324			
		18-22	3350														
		22-24	3450		3405	81	3324										
WR*																	
	4	00-09	5500	400	5100	1676	3424										
SR*^	1st October 2021 to 31st	09-16	4600	400	4200	1676	2524										
	October 2021	16-24	5500	400	5100	1676	3424										
Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).																	

^SR Export TTC/ATC figures have been calculated considering 01 unit (800 MW) at Kudgi TPS in service. The figures are subject to change with change in generation at Kudgi TPS.

Limiting	Constraints (Corridor wise)						
_		Applicable Revisions					
Corridor	Constraint						
	N-1 contingency of 1500 MVA, 765/400 kV ICT at Agra will overload the other ICT	Rev 0					
WR-NR	N-1 contingency of 1000 MVA, 765/400 kV ICT at Orai will overload the other ICT	Rev- 1 to 2					
	N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit	Rev- 3 to 12					
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli	Rev- 0 to 12					
ER-NR	Inter-regional flow pattern towards NR	Rev- 0 to 12					
	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT						
WR-SR	<b>R</b> N-1 of one ckt of 765kV Angul-Srikakulam D/C will overload the other circuit						
and ER-	Low Voltage at Gazuwaka (East) Bus.						
SR	N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT	Rev- 5 to 12					
	Low Voltage at Gazuwaka (East) Bus.	100 5 10 12					
SR-WR	a) N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt b) N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	Rev- 0 to 12					
ER-NER	<ul> <li>a) N-1 contingency of 400 kV Bongaigaon - Azara line</li> <li>b) High Loading of 220 kV Salakati - BTPS D/C</li> </ul>	Rev- 0 to 12					
NER-ER	<ul> <li>a) N-1 contingency of 220 kV Salakati - Alipurduar I or II</li> <li>b) High Loading of 220 kV Salakati - Alipurduar II or I</li> </ul>	Rev- 0 to 12					
W3 zone Injection		Rev- 0 to 12					

## Limiting Constraints (Simultaneous)

			Applicable Revisions	
		Inter-regional flow pattern towards NR	Rev- 0 to 12	
NR	Import	N-1 contingency of 1000 MVA, 765/400 kV ICT at Orai will overload the other ICT	Rev- 0 to 2	
		N-1 contingency of one ckt of 765 kV Vindhyachal-Varanasi will overload the other circuit	Rev- 3 to 12	
	Export	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.	Rev- 0 to 12	
	Export	(n-1) contingency of 400 kV Saranath-Pusauli	Kev- 0 to 12	
		a) N-1 contingency of 400 kV Bongaigaon - Killing line (0000 hrs to 2400 hrs)		
	Import	b) High Loading of 220 kV Balipara-Sonabil (0000 hrs to 0700 hrs)	Rev- 0 to 12	
NER		c) High Loading of 220 kV Salakati - BTPS D/C (0700 hrs to 1200 hrs)		
	<b>F</b>	a) N-1 contingency of 220 kV Salakati - Alipurduar I or II	D 0 ( 12	
	Export	b) High Loading of 220 kV Salakati - Alipurduar II or I	Rev- 0 to 12	
		N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT		
		N-1 of one ckt of 765kV Angul-Srikakulam D/C will overload the other circuit	Rev- 0 to 4	
	Import	Low Voltage at Gazuwaka (East) Bus		
SR		N-1 of one ICT of 765/400 kV, 1500 MVA ICT at Nizamabad will overload the other ICT	Rev- 5 to 12	
		Low Voltage at Gazuwaka (East) Bus	Kev- 3 to 12	
	Export	N-1 contingency of one ckt of 400 kV Kolhapur-PG - Kolhapur-MS D/C will overload of the other ckt	Rev- 0 to 12	
	Export	N-1 contingency of 500 MVA ICT at 400 kV Kolhapur-MS will overload the other 2x315 MVA ICTs	Kev- 0 to 12	

## National Load Despatch Centre Total Transfer Capability for October 2021

Revision No	Date of Revision	Period of Revision	Reason for Revision/Comment	Corridor Affected
1	17th July 2021	Whole month	Revised Reliability Margin (TRM) considering 2% of the total anticipated peak demand met in MW in NR Import	WR-NR, ER-NR & NR Import
			Revised STOA margin due to - a) Increase in LTA from Rihand to MP by 4.5MW (from 45 MW to 49.5 MW) b) Increase in LTA from Matalia to MP by 40 MW (from 10 MW to 50 MW) c) Decrease in LTA from Rajasthan solar to MP by 5 MW (from 10 MW to 5 MW) d) Increase in LTA from Rajasthan solar to Chattisgarh by 5 MW (from 5 MW to 10 MW) e) ARERJL MTOA of 200 MW to Maharashtra has ended f) NR ISGS allocation to Gujrat increased from 58 MW to 80 MW	NR-WR/ NR Export
2	28th July 2021	Whole month	Revised STOA margin due to - a) Increase in LTA from RWE_APL2_SECI-III(Ghadsisa) to Haryana by 22 MW (from 241 MW to 263 MW) b) LTA of 228 MW from PGLR_SREPL to UPPCL (SR-WR-NR) c) LTA of 6.9 MW from Rajghat, MP to UPPCL	WR-NR/NR Import
			Revised STOA as unallocated power of 300 MW from NTPC-WR to Karnataka revised to 0 MW	WR-SR/ SR Import
			Revised STOA margin due to LTA of 228 MW from PGLR_SREPL to UPPCL (SR-WR- NR)	SR-WR/SR Export
3	24th August, 2021	Whole Month	Revised TTC/ATC due to commissioning of 765kV Vindhyachal-Varanasi D/C	WR-NR, ER-NR & NR Import
			Revised STOA margin due to increase in LTA from PGLR_SREPL to UP by 12 MW (from 228MW to 240 MW)	SR-WR/SR Export; WR- NR/NR Import
4	28th August, 2021	Whole Month	Revised STOA margin due to operationalisation of LTA of 73 MW from Tuticorin- BETAMWIND to UPPCL (SR-ER-NR)	ER-NR/NR Import
			Revised STOA margin due to change in LTA allocations	NR-ER
			Revised STOA margin due to change in LTA allocations	NER Import/Export
5	25th September 2021	Whole Month	TTC/ATC revised due to commissioning of HVDC Raigarh-Pugalur Pole-3	WR-SR/ER-SR/SR Impor
			Revised STOA margin due to a)operationalization of new LTA OF 73 MW from Tuticorin-BETAMWIND to UPPCL b)operationalization of new LTA OF 10 MW from Tuticorin-IWISL to Haryana	WR-NR/NR Import
	28th September		Revised STOA margin due to a) Discontinuation of 250 MW MTOA from ACSEPL to Madhya Pradesh b) Operationalization of new LTA of 250 MW from RSWPL3_FTG2 to BSPHCL c) Operationalization of new LTA of 300 MW from AP43PL_BKN to Odisha	ER-NR/WR-NR/NR Export
6	2021	Whole Month	Revised STOA margin due to a)operationalization of new LTA of 106 MW from Fatehgarh-II Solar to Telangana b) operationalization of new LTA of 176 MW from Bhadla-II Solar to Telangana	WR-SR/SR Import
			Revised STOA margin due to a) Increase LTA by 6 MW from BETAM to UP (NR) b) Increase LTA by 15 MW from Spring Energy,Pugalur to UP (NR) c) Operationalization of 63 MW LTA fromHIRIYUR_OSTROKANNADA to Bihar, ER	SR-WR/SR Export
			Revised STOA margin due to discontinuation of 50 MW MTOA Arunachal Pradesh to NPCL(UP)	NER-ER/NER Export
7	29th September 2021	Whole Month	<ol> <li>Change in Load-Generation of NER</li> <li>Two units of Kameng HEP (4x150 MW) are under force outage</li> </ol>	ER-NER/NER Import/NER-ER/NER Export
		1st to 10th October 2021	ATC/TTC Curtailed due to shutdown of 765 kV Wardha - Aurangabad - 3 & 4	ER-SR/WR-SR/SR Impor
8	5th October 2021	6th October 2021	Due to emergency shutdown of 765 kV Raichur Sholapur - 2	WR-SR/SR Import
9	6th October 2021	8th October 2021	TTC/ATC Revised due to Shutdown of 765 kV Orai - Aligarh - 1	WR-NR, ER-NR & NR Import
10	7th October 2021	9th October 2021	TTC/ATC Revised due to Shutdown of 765 kV Agra - Gwalior - 2	WR-NR, ER-NR & NR Import
11	8th October 2021	9th October 2021	TTC/ATC Revised due to forced outage of HVDC Bhadrawati Pole 1	ER-SR/WR-SR/SR Impor
12	8th October 2021	10th October 2021	TTC/ATC Curtailed to Facilitate Testing of HVDC Raigarh - Pugalur	WR-SR/SR Import

				Month : October 2021	
S.No.	Name of State/Area		Load	Gener	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
Ι	NORTHERN REGION				
1	Punjab	10744	10867	3971	3971
2	Haryana	9492	9088	2701	2701
3	Rajasthan	10485	9635	8259	8259
4	Delhi	5321	5152	796	795
5 6	Uttar Pradesh Uttarakhand	20631 2124	20099 1886	10623 928	10689 939
7	Himachal Pradesh	1354	1114	783	769
8	Jammu & Kashmir	2363	1962	884	883
9	Chandigarh	313	249	0	0
10	ISGS/IPPs	48	48	21958	20013
	Total NR	62875	60100	50903	49019
П	EASTERN REGION				
1	Bihar	6537	5617	356	349
2	Jharkhand	1958	1503	511	501
3	Damodar Valley Corporation	2985	2723	5856	4190
4	Orissa	4513	4310	3998	3798
5	West Bengal	9704	8401	7033	6210
6	Sikkim	119	116	0	0
7	Bhutan	181	181	2325	2325
8	ISGS/IPPs	810	810	15771	11533
	Total ER	26808	23662	35850	28906
	WESTERN REGION	17105	10500	11001	40700
1	Maharashtra	17405	16509	11624	10789
2	Gujarat	13918	11320	8601	7246
3	Madhya Pradesh	9254	8534	3596	3845
4	Chattisgarh	4309	3965	2531	2835
5 6	Daman and Diu Dadra and Nagar Haveli	276 744	236 870	0	0
6 7	Goa-WR	534	420	0	0
8	ISGS/IPPs	1784	3263	36712	32338
0	Total WR	48224	45117	63064	57053
	Total Wite	40224	-0117	00004	07000
IV	SOUTHERN REGION				
1	Andhra Pradesh	8024	7220	6268	5204
2	Telangana	9100	8117	5196	5078
3	Karnataka	8396	6654	6023	4850
4	Tamil Nadu	15210	13068	7256	6376
5	Kerala	3778	2349	1614	961
6	Pondy	264	264	0	0
7	Goa-SR	82	82	0	0
8	ISGS/IPPs	37	37	14805	14794
	Total SR	44891	37791	41162	37263
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	140	95	118	118
2	Assam	1849	1588	615	574
3	Manipur	207	86	105	103
4	Meghalaya	315	255	302	229
5	Mizoram	150	55	60	60 93
6 7	Nagaland	173 435	155	96	
8	Tripura ISGS/IPPs	435 0	260 0	300 2371	300 2370
0	Total NER	3269	2494	3967	3847
	I ULAI INER	5209	2434	3907	3047
	Total All India	186067	169164	194946	176088