## National Load Despatch Centre Total Transfer Capability for September 2016

Issue Date: 26/8/2016 Issue Time: 1730 hrs Revision No. 2

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR-WR *	1st Sep 2016 to 30th Sep 2016	00-24	2500	500	2000	55	1945		
WR-NR*	1st Sep 2016 to 30th Sep 2016	00-24	6800	500	6300	6170	130		
		00.06	2000		1900	93	1707	ı	
NR-ER*	1st Sep 2016 to	00-06 06-18'	2000	200	1800 1800	158	1642		
NK-EK	30th Sep 2016	18-24	2000	200	1800	93	1707		
ER-NR*	1st Sep 2016 to	00-24	4400	300	4100	2531	1569		
	30th Sep 2016								
W3-ER <sup>\$</sup>	1st Sep 2016 to 30th Sep 2016	00-24		No limit is being specified.					
ER-W3	1st Sep 2016 to 30th Sep 2016	00-24	No limit is being specified.						
WR-SR	1st Sep 2016 to 30th Sep 2016	00-24	4000	750	3250	3250	0		
SR-WR *	1st Sep 2016 to 30th Sep 2016	00-24				No limit is	s being Specified.		
		00.06	Γ			2142	509	I	STOA margin revised due to outage
	1st Sep 2016 to	00-06	2650	0	2650	2207	508 443		of Talcher Stage-2 Unit -6 approved
	13th Sep 2016	18-24	2030	U	2030	2142	508		in 121st OCC of SRPC.
ER-SR	14th Sep 2016	00-06				2585	65		III 121st dee of SRI C.
	to 30th Sep	06-18'	2650	0	2650	2650	0		
SR-WR *	2016	18-24		-	0 2030	2585	65		
SR-ER *	1st Sep 2016 to 30th Sep 2016	00-24					s being Specified.	L	
ER-NER	1st Sep 2016 to 30th Sep 2016	00-17 23-24	1030	45	985	210	775		
	30th Sep 2016	17-23	940		895		685		
NER-ER	1st Sep 2016 to	00-17 23-24	1530	45	1485	0	1485		
	30th Sep 2016	17-23	1500		1455		1455		
W3 zone Injection	1st Sep 2016 to 30th Sep 2016	00-24	No limit is b	eing specified	d (In case of an	y constraints appea	aring in the system	W3 zone e	export would be revised accordingly)

Note: TTC/ATC of S1-S2 corridor, Import of Punjab and Import of DD & DNH is uploaded on NLDC website under Intra-Regional Section in Monthly ATC.

<sup>\*</sup> Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

### National Load Despatch Centre Total Transfer Capability for September 2016

Issue Date: 26/8/2016 Issue Time: 1730 hrs Revision No. 2

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
----------	------	-------------------------	--	-----------------------	--	--	--	---	----------

- 1) S1 comprises of Telangana, AP and Karnataka: S2 comprises of Tamil Nadu, Kerala and Puducherry
- 2) W3 comprises of the following regional entities:
- a) Chattisgarh Sell transaction, b) Jindal Power Limited (JPL) Stage-I & Stage-II, c) Jindal Steel and Power Limited (JSPL), d) ACBL, e) LANCO Amarkantak
- f) BALCO, g) Sterlite (#1,3,4), h) NSPCL, i) Korba, j) Sipat, k) KSK Mahanadi, L)DB Power, m) KWPCL, n)Vandana Vidyut o)RKM, p)GMR Raikheda, q)Ind Barath and any other regional entity generator in Chhattisgarh

# The figure is based on LTA/MTOA approved by CTU and Allocation figures as per RPCs RTA/REA. In actual Operation, due to Units being on Maintenance/Fuel shortage/New units being commissionned the LTA/MTOA utilized would vary. RLDC/NLDC would factor this situation on day-ahead basis. In the eventuality that net schedules exceed ATC, real time curtailments might be effected by RLDCs/NLDC.

In case of TTC Revision due to any shutdown:

- 1) The TTC value will be revised to normal values after restoration of shutdown.
- 2) The TTC value will be revised to normal values if the shutdown is not being availed in real time.

#### **Limiting Constraints**

Corridor	Constraint
NR-WR	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak
WR-NR	1. (n-1) Contingnecy of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit.  2. High Loading of 400kV Singrauli-Anpara S/C.
NR-ER	(n-1) contingency of 400 kV Saranath-Pusauli
ER-NR	n-1 contingency of one cicuit of 400 kV Biharshariff- Lakhisarai leads to high loading on the other cicuit
WR-SR & ER-SR	(n-1) contingency of one circuit of 765 kV Raichur - Sholapur will lead to 2500 MW loading on the other circuit
EK-SK	Low Voltage at Gazuwaka (East) Bus.
ER-NER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa. n-1 contingency of 400/132 kV, 2 x 200 MVA ICTs at Silchar
NER-ER	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA ICT at Misa
W3 zone Injection	

### **Simultaneous Import Capability**

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
ER									
		00-05	9700		8900		199		
NR* 1st Sep 2016 to 30th Sep 2016		05-18'	9700	000	8900	0704	199		
		18-23'	9700	800	8900	8701	199	,	
	23-24	9700		8900		199			
NER	1st Sep 2016 to	00-17 23-24	1030	45	985	210	775		
	30th Sep 2016	17-23	940		895		685		
WR									
	1 . 0 . 2016 .	00-06	6650		5900	5392	508		STOA margin revised due
	1st Sep 2016 to 13th Sep 2016	06-18'	6650	750	5900	5457	443		to outage of Talcher Stage- 2 Unit -6 approved in 121st
SR	13th 5cp 2010	18-24	6650		5900	5392	508		OCC of SRPC.
	141 9 2016	00-06	6650		5900	5835	65		
	14th Sep 2016 to 30th Sep 2016	06-18'	6650	750	5900	5900	0		
	20m 20p 2010	18-24	6650		5900	5835	65		

<sup>\*</sup> Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

Margin in Simultaneous import of NR = A

WR-NR ATC =B

ER-NRATC = C

Margin for WR-NR applicants = A \* B/(B+C)Margin for ER-NR Applicants = A \* C/(B+C)

<sup>\*</sup> For approving STOA Bilateral transactions, margin available in Simultaneous Import of NR would be apportioned on WR-NR Corridor & ER-NR Corridor in the following ratio:

## **Simultaneous Export Capability**

Corridor	Date	Time Period (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
NR*	1st Sep 2016 to 30th Sep 2016	00-06 06-18' 18-24	4500 4500	700	3800 3800	148 213 148	3652 3587		
NER	1st Sep 2016 to 30th Sep 2016	00-17 23-24	1530	45	3800 1485	0	3652 1485		
WR	30th Sep 2010	17-23	1500		1455		1455		
SR *	1st Sep 2016 to 30th Sep 2016	00-24				No limit is be	ing Specified.		

<sup>\*</sup> Fifty Percent (50 % ) Counter flow benefit on account of LTA/MTOA transactions in the reverse direction would be considered for advanced transactions (Bilateral & First Come First Serve).

## **Limiting Constraints**

	, 001181111111						
NR NER -		(n-1) contingency of one circuit of 400 kV Biharshariff- Lakhisarai leads to high loading on the other circuit					
	Import	1. (n-1) Contingnecy of 765kV Gwalior-Agra one ckt leads to 2750 MW loading on second circuit.					
		2.High Loading of 400kV Singrauli-Anpara S/C.					
	Ermont	(n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak.					
	Export	(n-1) contingency of 400 kV Saranath-Pusauli					
	T 04	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA					
NED	Import	ICT at Misa. n-1 cntingency of 400/132 kV, 2 x 200 MVA ICTs at Silchar					
NEK	2.High Loading of 400kV Singrauli-Anpara S/C.  Export  (n-1) contingency of 400kV Zerda-Bhinmal and (n-1) contingency of 220kV Badod-Modak. (n-1) contingency of 400 kV Saranath-Pusauli  (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 k' ICT at Misa. n-1 cntingency of 400/132 kV, 2 x 200 MVA ICTs at Silchar  (n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 k' ICT at Misa.	(n-1) contingency of 400/220 kV, 2x315 MVA ICTs at Misa results in high loading of other 400/220 kV, 315 MVA					
	Export	ICT at Misa.					
SR	Import	(n-1) contingency of one circuit of 765 kV Raichur - Sholapur will lead to 2500 MW loading on the other circuit					
SK	Import	Low Voltage at Gazuwaka (East) Bus.					

# National Load Despatch Centre Total Transfer Capability for September 2016

Revisio n No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected
1	08-01-16	montn	STOA margin revised due to change in LTA/MTOA allocation Revised due to commissioning of 400 kV Ranchi-Chandawa- Gaya D/C, 765kV Varanasi-Kanpur D/C, 765kV Kanpur- Jhatikara S/C, 400kV Kanpur (GIS)-Kanpur D/C and conisdering total gen at Kawai, Chhabra, Kalisindh as 2500 MW and considering the present inter regional flow pattern	NR-ER/ NR-WR/ Simulaneous Export of NR WR-NR/ Simultaneous import of NR
2	26-08-16		STOA margin revised due to outage of Talcher Stage-2 Unit - 6 approved in 121st OCC of SRPC.	ER-SR/ Import of SR

ASSU	MPTIONS IN BASECASE				
				Month : September '16	
S.No.	Name of State/Area	Load		Generation	
		Peak Load (MW)	Off Peak Load (MW)	Peak (MW)	Off Peak (MW)
l	NORTHERN REGION				
1	Punjab	9400	8059	5466	5258
2	Haryana	7798	7260	2610	2610
3	Rajasthan	10027	10099	6333	6382
4	Delhi	4844	4498	962	962
5	Uttar Pradesh	13618	12577	7131	7179
6	Uttarakhand	1688	1250	804	722
7	Himachal Pradesh	1184	901	815	850
8	Jammu & Kashmir	2246	1356	841	807
9	Chandigarh	286	191	0	0
10	ISGS/IPPs	0	0	20482	15017
	Total NR	51091	46191	45444	39787
II	EASTERN REGION				
1	Bihar	3260	2746	200	110
2	Jharkhand	1023	883	400	350
3	Damodar Valley Corporation	2582	2207	3400	2871
4	Orissa	3708	2852	2929	2000
5	West Bengal	7601	6081	4768	3830
6	Sikkim	93	49	0	0
7	Bhutan	215	215	1504	1472
8	ISGS/IPPs	415	419	9645	9015
	Total ER	18897	15452	22846	19647
III	WESTERN REGION				
1	Maharashtra	20103	13051	13552	9451
	Gujarat	14488	8693	11414	5676
	Madhya Pradesh	8537	5486	4790	2285
	Chattisgarh	4088	2975	3236	1989
	Daman and Diu	314	229	0	0
6	Dadra and Nagar Haveli	680	626	0	0
	Goa-WR	487	221	0	0
8	ISGS/IPPs	902	904	28078	22617
	Total WR	49599	32185	61071	42019

V	SOUTHERN REGION				
1	Andhra Pradesh	7073	5389	6385	5627
2	Telangana	9564	7551	4263	2964
3	Karnataka	9054	7496	6966	5130
4	Tamil Nadu	14003	12691	7036	5417
5	Kerala	3973	2663	1643	638
6	Pondy	391	327	0	0
7	Goa-SR	89	89	0	0
8	ISGS/IPPs	28	28	14187	11953
	Total SR	44175	36234	40480	31729
V	NORTH-EASTERN REGION				
1	Arunachal Pradesh	130	102	0	0
2	Assam	1228	1007	275	225
3	Manipur	164	76	0	0
4	Meghalaya	279	206	300	243
5	Mizoram	93	63	8	0
6	Nagaland	120	84	24	16
7	Tripura	234	148	91	91
8	ISGS/IPPs	100	60	1869	1763
	Total NER	2348	1746	2567	2338
	Total All India	166356	132052	173941	136992