National Load Despatch Centre Import of Punjab Transfer Capability for September 2019

Issue Date: 28th May 2019

Issue Time: 1400 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st September 19 to 30th September 19	00-24	6800	600	6200	4580	1620		
Limiting Constraints		 (N-1) contingency of 500 MVA ICT at Amritsar (PG), Rajpura and N-1 contigency of 315 MVA ICT at Muktsar will critically load other ICTs. 220 kV underlying network at Ludhiana and Amritsar 						

National Load Despatch Centre Import of Punjab Transfer Capability for September 2019

Revision	Date of	Period of	Reason for Revision		
No	Revision	Revision			