## Natioanl Load Despatch Centre, New Delhi Transfer Capability between S1- (S2&S3) for June 2019

Issue Date: 28 February 2019 Issue Time: 1800 Hrs Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Jun 2019 to 30th Jun 2019	00 - 24	9600	490	9110	3585	5525		
Constraints (any	i. (n-1) of one line of 400kV Mettur – Karamadai will lead to Low Voltage at 400kV Karamadai SS  ii. (n-1) contingency of one circuit of 400 kV Hosur - Salem will lead to overloading of the other circuit  iii. (n-1) contingency of one circuit of 400 kV Kolar-Hosur will lead to overloading of the other circuit  iv. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to overloading of the other circuit  v. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and Syst Protection Shcheme (SPS)						ad in North Kerala and System	

## Natioanl Load Despatch Centre, New Delhi Transfer Capability for Import of S3 for June 2019

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Jun 2019 to 30th Jun 2019	00-24	2900	90	2810	2727	83		
Constraint (any one or combination	i. (n-1) contingency of one ckt of 400kV Udumalpet - Palakkad will lead to overloading of the other circuit * ii. Low Voltage in Kerala (S3)							
Note-2	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala (n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

## National Load Despatch Centre Transfer Capability between S1- (S2&S3) for June 2019 Transfer Capability for Import of S3 for June 2019

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
0	2/28/2019	01-06-2019	Revision-0	_
		to 30-06-2019		