## Natioanl Load Despatch Centre, New Delhi Transfer Capability between S1- (S2&S3) for June 2019

Issue Date: 31st May 2019 Issue Time: 1230 Hrs Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments	
1st Jun 2019	00 - 24	8640	490	8150	3606	4544		Revision in TTC/ATC figures due to change in June'19 Load Generation Balance.	
2nd Jun 2019 to 20th Jun 2019	00 - 24	8640	490	8150	3656	4494	-960		
21st Jun 2019 to 24th Jun 2019	00 - 24	8640	490	8150	3606	4544			
25th Jun 2019 to 30th Jun 2019	00 - 24	8640	490	8150	3516	4634			
Limiting	i. (n-1) of one line of 400kV Mettur – Karamadai will lead to Low Voltage at 400kV Karamadai SS								
Constraints (any	ii. (n-1) contingency of one circuit of 400 kV Hosur - Salem will lead to overloading of the other circuit								
	iii. (n-1) contingency of one circuit of 400 kV Kolar-Hosur will lead to overloading of the other circuit iv. (n-1) contingency of one circuit of 400 kV Udumalpet-Palakkad will lead to overloading of the other circuit								
	v. Low Voltage in Kerala (S3)								
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala								
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)								

## Natioanl Load Despatch Centre, New Delhi Transfer Capability for Import of S3 for June 2019

Date	Time Period in IST (hrs)		Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA)	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Jun 2019	00-24	2940	90	2850	2689	161	40	Revision in TTC/ATC figures due to change in June'19 Load Generation Balance.
2nd Jun 2019 to 20th Jun 2019	00-24	2940	90	2850	2658	192		
21st Jun 2019 to 24th Jun 2019	00-24	2940	90	2850	2689	161		
25th Jun 2019 to 30th Jun 2019	00-24	2940	90	2850	2710	140		
T								
Limiting Constraint (any	i. (n-1) contingency of one ckt of 400kV Udumalpet - Palakkad will lead to overloading of the other circuit * ii. Low Voltage in Kerala (S3)							
Note-1	S1 comprises Andhra Pradesh, Telangana and Karnataka and Goa(SR); S2 comprises Tamil Nadu and Pondicherry; S3 comprises Kerala							
Note-2	(n-1) contingency of 400/220 ICT at Kozhikode is not considered while assessing TTC because of the radial nature of load in North Kerala and System Protection Shcheme (SPS)							

## National Load Despatch Centre Transfer Capability between S1- (S2&S3) for June 2019 Transfer Capability for Import of S3 for June 2019

F	Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor
	1	31st May 2019	I Whole Month	Change in June'19 Load Generation Balance. (OCC approved unit outages considered)	S1-(S2&S3) and S3