

GRID CONTROLLER OF INDIA LIMITED  
National Load Despatch Centre



From: The Shift Charge Manager, NLDC

To: The Shift Charge Manager, SRLDC

Date: 29/11/2023

Time: 12:23:39

Sl.No	Corridor	Current TTC(MW)	Current ATC(MW)	Revised TTC(MW)	Revised ATC(MW)	Change in ATC (MW)	Date for which Revision is done(dd-mm-yyyy)	Time Block for Revision(From TB)	Time Block for Revision(To TB)	Reason for Revision/Event for which TTC/ATC Revision is being done
1	S1-(S2&S3)	9500	9050	8600	8150	-900	2023-11-29	54	96	400KV/230KV VELLALAVIDUTHI-ICT-4 emergency shutdown has been requested form 12:00hrs, in view of the shutdown TTC/ATC reduction of of S1-(S2&S3) is 900MW

SCE-NLDC