

पावर सिस्टम ऑपरेशन कॉपरिशन राष्ट्रीय भार प्रेषण केंद्र

बी-9, कुतुब इन्स्टीट्यूशनल एरिया,
कटवारिया सराय, नई दिल्ली- 110016



17

सदेश स. १६ Message No:

045

दिनांक Date: 13/03/22

समय Time: 15:35

प्रेषक:/From: पाली प्रभारी प्रबन्धक, रा.भा.प्रे.क. /Shift Charge Manager, NLDC

सेवा में/To: पाली प्रभारी प्रबन्धक, /Shift Charge Manager.

W-e-f. 16:30 hours of
13/03/2022

उ.क्षे.भा.प्रे.के. NRLDC	प.क्षे.भा.प्रे.के. WRLDC	द.क्षे.भा.प्रे.के. SRLDC	पू.क्षे.भा.प्रे.के. ERLDC	उ.पू.क्षे.भा.प्रे.के. NERLDC
-----------------------------	-----------------------------	-----------------------------	------------------------------	---------------------------------

विषय/Sub: विद्युत प्रणाली तत्वों के ट्रिपिंग/रिवाइवल के कारण टीटीसी/एटीसी में सेसोधन
Revision of TTC/ATC on account of Tripping/revival of power system elements

क्रम सं. S. No	कॉरिडोर Corridor	वर्तमान टीटीसी (मे. वा.) Current TTC (MW)	वर्तमान एटीसी (मे. वा.) Current ATC (MW)	संसोधित टीटीसी (मे. वा.) Revised TTC (MW)	संसोधित एटीसी (मे. वा.) Revised ATC (MW)	समय खंड Time Blocks	कारण Reason
1.	WR-SR	10300	9650	11600	10950	67-96	Due to revival of HVDC Kalgank Pugalkur Pole-3
2.	SR Import	16000	15000	17300	16300	67-96	
3.	SR Export	5550	5150	6350	5950	67-96	
4.	SR-WR	6600	6200	7400	7000	67-96	

पाली प्रभारी प्रबन्धक / Shift Charge Manager

111

Handwritten notes, possibly a list or a series of entries, covering the middle section of the page.

Handwritten notes at the bottom of the page, including a signature and some concluding remarks.