

# पावर सिस्टम ऑपरेशन कॉपरिशन राष्ट्रीय भार प्रेषण केंद्र

बी-9, कुतुब इन्स्टीट्यूशनल एरिया,  
कटवारिया सराय, नई दिल्ली- 110016



संदेश स. १६ Message No: 071

दिनांक Date: 06/11/22  
समय Time: 09:00

प्रेषक:/From: पाली प्रभारी प्रबन्धक, रा.भा.प्रे.क. /Shift Charge Manager, NLDC

सेवा में/To: पाली प्रभारी प्रबन्धक, /Shift Charge Manager.

उ.क्षे.भा.प्रे.के. NRLDC	प.क्षे.भा.प्रे.के. WRLDC	द.क्षे.भा.प्रे.के. SRLDC	पू.क्षे.भा.प्रे.के. ERLDC	उ.पू.क्षे.भा.प्रे.के. NERLDC
-----------------------------	-----------------------------	-----------------------------	------------------------------	---------------------------------

विषय/Sub: विद्युत प्रणाली तत्वों के ट्रिपिंग/रिवाइवल के कारण टीटीसी/एटीसी में सेसोधन  
Revision of TTC/ATC on account of Tripping/revival of power system elements

wef 10:00hrs till  
24:00hrs of 06/11/22.

क्रम सं S. No	कॉरिडोर Corridor	वर्तमान टीटीसी (मे. वा.) Current TTC (MW)	वर्तमान एटीसी (मे. वा.) Current ATC (MW)	संसोधित टीटीसी (मे. वा.) Revised TTC (MW)	संसोधित एटीसी (मे. वा.) Revised ATC (MW)	समय खंड Time Blocks	कारण Reason
1)	Import of punjab	9000	8500	9400	8900	41-96	due to tripping of Talwandi Subo Unit 2

पाली प्रभारी प्रबन्धक / Shift Charge Manager

शैलेन्द्र वर्मा



The following text is extremely faint and illegible. It appears to be a list or a series of entries, possibly containing names and dates, but the characters are too light to be accurately transcribed.

