GRID CONTROLLER OF INDIA LIMITED National Load Despatch Centre



From: The Shift Charge Manager, NLDC

To: The Shift Charge Manager, NRLDC/WRLDC/ERLDC

Date: 5/24/2023 Time: 1:07:57 PM

| SI.No | Corridor | Current TTC(MW) | Current ATC(MW) | Revised TTC(MW) | Revised ATC(MW) | Change in ATC (MW) | Date for which Revision is done(dd-mm-yyyy) | Time Block for Revision(From TB) | Time Block for Revision(To TB) | Reason for Revision/Event for which TTC/ATC Revision is being done |
|-------|-----------|--------------------|--------------------|--------------------|--------------------|--------------------------|---|--|---|--|
| 1 | WR-NR | 17800 | 16800 | 17100 | 16100 | -700 | 2023-05-24 | 56 | 96 | Due to the tripping of HVDC Mundra Mohindergarh Pole-2 |
| 2 | ER-NR | 8000 | 7600 | 7800 | 7400 | -200 | 2023-05-24 | 56 | 96 | Due to the tripping of HVDC Mundra Mohindergarh Pole-2 |
| 3 | NR_IMPORT | 25800 | 24400 | 24900 | 23500 | -900 | 2023-05-24 | 56 | 96 | Due to the tripping of HVDC Mundra Mohindergarh Pole-2 |
| 4 | NR-WR | 4000 | 3500 | 2900 | 2400 | -1100 | 2023-05-24 | 56 | 96 | Due to the tripping of HVDC Mundra Mohindergarh Pole-2 |
| 5 | NR_EXPORT | 4000 | 3500 | 2900 | 2400 | -1100 | 2023-05-24 | 56 | 96 | Due to the tripping of HVDC Mundra Mohindergarh Pole-2 |

SCE-NLDC