

**GRID CONTROLLER OF INDIA LIMITED**  
**National Load Despatch Centre**



From: The Shift Charge Manager, NLDC

To: The Shift Charge Manager, WRLDC/ERLDC/SRLDC

Date: undefined  
Time: undefined

Sl.No	Corridor	Current TTC(MW)	Current ATC(MW)	Revised TTC(MW)	Revised ATC(MW)	Change in ATC (MW)	Date for which Revision is done(dd-mm-yyyy)	Time Block for Revision(From TB)	Time Block for Revision(To TB)	Reason for Revision/Event for which TTC/ATC Revision is being done
1	SR-WR	6500	5850	6250	5600	-250	2023-07-22	42	96	An emergency Shutdown on Pole-1 at Bhadravati ,for rectification of faulty thyristor levels
	SR_EXPORT	5200	4550	4950	4300	-250	2023-07-22	42	96	An emergency Shutdown on Pole-1 at Bhadravati ,for rectification of faulty thyristor levels
	ER-SR	5700	5350	5550	5200	-150	2023-07-22	42	96	An emergency Shutdown on Pole-1 at Bhadravati ,for rectification of faulty thyristor levels
	WR-SR	11600	10950	10700	10050	-900	2023-07-22	42	96	An emergency Shutdown on Pole-1 at Bhadravati ,for rectification of faulty thyristor levels
	SR_IMPORT	17300	16300	16250	15250	-1050	2023-07-22	42	96	An emergency Shutdown on Pole-1 at Bhadravati ,for rectification of faulty thyristor levels

SCE-NLDC