

GRID CONTROLLER OF INDIA LIMITED
National Load Despatch Centre



From: The Shift Charge Manager, NLDC

To: The Shift Charge Manager, ERLDC/NERLDC

Date: 14/01/2024

Time: 19:32:51

| Sl.No | Corridor | Current TTC(MW) | Current ATC(MW) | Revised TTC(MW) | Revised ATC(MW) | Change in ATC (MW) | Date for which Revision is done(dd-mm-yyyy) | Time Block for Revision(From TB) | Time Block for Revision(To TB) | Reason for Revision/Event for which TTC/ATC Revision is being done |
|-------|------------|-----------------|-----------------|-----------------|-----------------|--------------------|---|----------------------------------|--------------------------------|--|
| 1 | ER-NER | 1500 | 1440 | 1700 | 1640 | 200 | 2024-01-14 | 83 | 84 | Due to revival of 220kV APD-SALAKATi-1&2 |
| 2 | ER-NER | 1850 | 1790 | 2075 | 2015 | 225 | 2024-01-14 | 85 | 96 | Due to revival of 220kV APD-SALAKATi-1&2 |
| 3 | NER-ER | 1700 | 1640 | 2900 | 2840 | 1200 | 2024-01-14 | 83 | 96 | Due to revival of 220kV APD-SALAKATi-1&2 |
| 4 | NER_IMPORT | 1000 | 940 | 1200 | 1140 | 200 | 2024-01-14 | 83 | 84 | Due to revival of 220kV APD-SALAKATi-1&2 |
| 5 | NER_IMPORT | 1350 | 1290 | 1575 | 1515 | 225 | 2024-01-14 | 85 | 96 | Due to revival of 220kV APD-SALAKATi-1&2 |
| 6 | NER_EXPORT | 2200 | 2140 | 3400 | 3340 | 1200 | 2024-01-14 | 83 | 96 | Due to revival of 220kV APD-SALAKATi-1&2 |

SCE-NLDC