

GRID CONTROLLER OF INDIA LIMITED  
National Load Despatch Centre



From: The Shift Charge Manager, NLDC

To: The Shift Charge Manager, NRLDC/WRLDC/ERLDC

Date: 6/17/2024  
Time: 2:34:31 PM

Sl.No	Corridor	Current TTC(MW)	Current ATC(MW)	Revised TTC(MW)	Revised ATC(MW)	Change in ATC (MW)	Date for which Revision is done(dd-mm-yyyy)	Time Block for Revision(From TB)	Time Block for Revision(To TB)	Reason for Revision/Event for which TTC/ATC Revision is being done
1	WR-NR	22150	21150	19600	18600	-2550	2024-06-17	89	96	1. Due to more than 11 number of incidents involving loss of simultaneous outage of more than one pole of HVDC Champa-Kuruchetra link since Jan 2024 2. Due to widespread load loss in NR and generation loss in All India Power System during outage of 4 poles of HVDC Champa-Kuruchetra at 13:53 hrs on 17.06.24 event in under investigation
2	ER-NR	6700	6300	6350	5950	-350	2024-06-17	89	96	
3	NR_IMPORT	24950	23550	22050	20650	-2900	2024-06-17	89	96	

SCE-NLDC