

GRID CONTROLLER OF INDIA LIMITED
National Load Despatch Centre



From: The Shift Charge Manager, NLDC

To: The Shift Charge Manager, NRLDC/WRLDC/ERLDC

Date: 6/30/2023
Time: 10:47:28 AM

Sl.No	Corridor	Current TTC(MW)	Current ATC(MW)	Revised TTC(MW)	Revised ATC(MW)	Change in ATC (MW)	Date for which Revision is done(dd-mm-yyyy)	Time Block for Revision(From TB)	Time Block for Revision(To TB)	Reason for Revision/Event for which TTC/ATC Revision is being done
1	WR-NR	17800	16800	17750	16750	-50	2023-06-30	49	96	Hotspot (107.6 Degrees) has been detected in B-ph Line Isolator (71089L) of 765KV Gaya-Varanasi-I Line at Gaya SS.
2	ER-NR	8000	7600	7950	7550	-50	2023-06-30	49	96	Hotspot (107.6 Degrees) has been detected in B-ph Line Isolator (71089L) of 765KV Gaya-Varanasi-I Line at Gaya SS.
3	NR_IMPORT	25800	24400	25700	24300	-100	2023-06-30	49	96	Hotspot (107.6 Degrees) has been detected in B-ph Line Isolator (71089L) of 765KV Gaya-Varanasi-I Line at Gaya SS.

SCE-NLDC