

GRID CONTROLLER OF INDIA LIMITED
National Load Despatch Centre



From: The Shift Charge Manager, NLDC

To: The Shift Charge Manager, NRLDC/WRLDC/ERLDC

Date: 8/6/2023
Time: 12:18:06 PM

Sl.No	Corridor	Current TTC(MW)	Current ATC(MW)	Revised TTC(MW)	Revised ATC(MW)	Change in ATC (MW)	Date for which Revision is done(dd-mm-yyyy)	Time Block for Revision(From TB)	Time Block for Revision(To TB)	Reason for Revision/Event for which TTC/ATC Revision is being done
1	ER-NR	7750	7350	8000	7600	250	2023-08-06	52	96	Due to non availing shutdown of 765 KV SATNA VINDHYACHAL (PS)
2	WR-NR	17300	16300	17800	16800	500	2023-08-06	52	96	Due to non availing shutdown of 765 KV SATNA VINDHYACHAL (PS)
3	NR_IMPORT	25050	23650	25800	24400	750	2023-08-06	52	96	Due to non availing shutdown of 765 KV SATNA VINDHYACHAL (PS)

SCE-NLDC